



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 2179

1. WELL CONTRACTOR:

Roger W. Jackson

Well Contractor (Individual) Name

Jackson Well Company

Well Contractor Company Name

STREET ADDRESS 5660 McDougald Road

Lillington, North Carolina 27546

City or Town State Zip Code

(910) 893-2372

Area code- Phone number

2. WELL INFORMATION:

SITE WELL ID # (if applicable) App 12-5-28302

STATE WELL PERMIT # (if applicable)

DEQ or OTHER PERMIT # (if applicable)

WELL USE (Check applicable box): Residential Water Supply

DATE DRILLED 2-29-12

TIME COMPLETED 11:00 AM/PM

3. WELL LOCATION:

CITY: Linden COUNTY: WAKE

193 FEROME LANE

Well Name, Location, Community, Subdivision, Lot No., Parcel, Zip Code

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Edge Other (check appropriate box)

LATITUDE 35 61247

LONGITUDE 78 84321

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: GPS Topographic map

(Location of well must be shown on a USGS topographic map and attached to file box if not using GPS)

4. WELL OWNER

OWNER'S NAME MICHAEL WATERS DINE

STREET ADDRESS 193 FEROME LANE

Linden NC 28356

City or Town State Zip Code

(910) 893-5188 315-247-6788

Area code- Phone number

5. WELL DETAILS:

a. TOTAL DEPTH: 260'

b. DOES WELL REPLACE EXISTING WELL? YES NO

c. WATER LEVEL Below Top of Casing: 22 FT. (Use "+" if Above Top of Casing)

d. TOP OF CASING IS 1 FT. Above Land Surface*
*Top of casing (inserted) after below land surface may require a variance in accordance with 15A NCAC 2C .0118.

ILD (gpm): 15 METHOD OF TEST Air

INSPECTION Type HTH Access 16oz

g. WATER ZONES (depth):

From 25' To 265' From _____ To _____

From _____ To _____ From _____ To _____

From _____ To _____ From _____ To _____

6. CASING:

From 0 To 200 Ft. Thickness 1/2" Material PVC

From _____ To _____ Ft. Thickness _____ Material _____

From _____ To _____ Ft. Thickness _____ Material _____

7. GROUT:

From 0 To 20 Ft. Material Sand/Grout Method pour

From _____ To _____ Ft. Material _____ Method _____

From _____ To _____ Ft. Material _____ Method _____

8. SCREEN:

From _____ To _____ Ft. Diameter _____ Slot Size _____ Material _____

From _____ To _____ Ft. Diameter _____ Slot Size _____ Material _____

From _____ To _____ Ft. Diameter _____ Slot Size _____ Material _____

9. SAND/GRAVEL PACK:

From _____ To _____ Ft. Size _____ Material _____

From _____ To _____ Ft. Size _____ Material _____

From _____ To _____ Ft. Size _____ Material _____

10. DRILLING LOG

From To Formation Description

0 162 CLAY

162 260 SLATE

11. REMARKS:

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Roger W. Jackson 3-26-12
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

Roger W. Jackson
PRINTED NAME OF PERSON CONSTRUCTING THE WELL