



North Carolina State Laboratory Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

P.O. Box 28047
4312 District Drive
Raleigh, NC 27611-8047
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

Report To:
HARNETT CO ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BLVD

Name of System:
BOBBY ELKINS

LILLINGTON, NC 27546
EIN:566000306EH

COURIER #: 14-73-01

RAWLS CHURCH RD
FUQUAY VARINA, NC 27526

StarLiMS Sample ID: ES012915-0025001



Collected: 01/28/2015 11:00
Received: 01/29/2015 07:42

James E Manhart
Denise Richardson

ES Microbiology ID:
GPS Number:

Sample Source: Well
Sampling Point: Outside spigot

Well Permit Number:

Sample Description:
Comment:

Environmental Microbiology - Colilert Profile

Method: SM 9223B

Test Name: Colilert

Analyte	Test Result	Analyst	Date
Total Coliform, Colilert	Absent	Denise Richardson	01/30/2015
<i>E. coli</i> , Colilert	Absent	Denise Richardson	01/30/2015

Report Date: 01/30/2015

Reported By: Susan Beasley

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.