



North Carolina State Laboratory of Public Health
 Environmental Sciences
 Inorganic Chemistry
 Certificate of Analysis

P.O. Box 28047
 4312 District Drive
 Raleigh, NC 27611-8047
<http://slph.ncpublichealth.com>
 Phone: 919-733-7308
 Fax: 919-715-8611

Report To: **ANDREW CURRIN**

Name of System:

HARNETT CO ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BLVD

SECURE INC

LILLINGTON, NC 27546
EIN: 566000306EH

Courier # 14-73-01

44 HILLBILLY LN
COATS, NC 27521

StarLiMS ID: **ES122117-0023001**

Date Collected: 12/20/17

Time Collected: 1:30 PM

Date Received: 12/21/17

Collected By: Andrew Currin

Sample Type: Raw
 Sample Source: New Well

Sampling Point: Well head
 Temp. at Receipt: 3.5

Well Permit #: 17-5-42816
 GPS #:

Sample Description:
 Comment:

New Well I (Profile)

| Analyte | Result | Allowable Limit | Unit | Qualifier(s) |
|------------------|----------|-----------------|------|--------------|
| Arsenic | < 0.005 | 0.010 | mg/L | |
| Barium | 0.430 | 2.00 | mg/L | |
| Cadmium | < 0.001 | 0.005 | mg/L | |
| Calcium | 78 | | mg/L | |
| Chloride | 85.00 | 250 | mg/L | |
| Chromium | < 0.01 | 0.10 | mg/L | |
| Copper | < 0.05 | 1.3 | mg/L | |
| Fluoride | < 0.20 | 4.00 | mg/L | |
| Iron | 2.90 | 0.30 | mg/L | |
| Lead | < 0.005 | 0.015 | mg/L | |
| Magnesium | 13 | | mg/L | |
| Manganese | 0.170 | 0.05 | mg/L | |
| Mercury | < 0.0005 | 0.002 | mg/L | |
| Nitrate | < 1.00 | 10.00 | mg/L | |
| Nitrite | < 0.1 | 1.00 | mg/L | |
| pH | 8.3 | | N/A | |
| Selenium | < 0.005 | 0.05 | mg/L | |
| Silver | < 0.05 | 0.10 | mg/L | |
| Sodium | 35.00 | | mg/L | |
| Sulfate | 12.00 | 250 | mg/L | |
| Total Alkalinity | 180 | | mg/L | |
| Total Hardness | 250 | | mg/L | |
| Zinc | 0.15 | 5.00 | mg/L | |

Report Date: 01/11/2018

Reported By: Debbie Moncol



Private Well Information and Use Recommendations

For Inorganic Chemical Contaminants

County:

Name:

Sample ID #:

Reviewer:

TEST RESULTS AND USE RECOMMENDATIONS

1. Your well water meets federal drinking water standards *for inorganic chemicals*. Your water can be used for drinking, cooking, washing, cleaning, bathing, and showering based on the *inorganic chemical results only*. You may have other water sampling results that are not taken into account in this report.
2. The following substance(s) exceeded federal drinking water standards or the North Carolina 2L calculated health levels. The North Carolina Division of Public Health recommends that your well water not be used for drinking and cooking, unless you install a water treatment system to remove the circled substance(s). However, it may be used for washing, cleaning, bathing and showering based on the *inorganic chemical results only*.

| | | | | | | | | |
|-----------|---------|-----------------|----------|--------|-----------|------|------|--|
| Arsenic | Barium | Cadmium | Chromium | Copper | Fluoride | Lead | Iron | |
| Manganese | Mercury | Nitrate/Nitrite | Selenium | Silver | Magnesium | Zinc | pH | |

3. a. Sodium levels exceed the U.S. Environmental Protection Agency's (USEPA) Health Advisory level for sodium of 20 mg/l. The North Carolina Division of Public Health recommends that only individuals on no or low sodium restricted diets not use this water for drinking or cooking. It may be used for washing, cleaning, bathing, and showering based on the *inorganic chemical results only*.
- b. Levels over 30 mg/l may pose aesthetic problems such as bad taste, odor, staining of porcelain, etc.
4. Re-sampling is recommended in _____ months.
5. Re-sample for lead and /or copper. Take a first draw, 5 minute, and 15 minute sample inside the house (preferably the kitchen) and if possible a first draw, 5 minute and a 15 minute sample at the well head to determine the source of the lead and/or copper.
6. The following substance(s) exceeded federal drinking water standards. Your water can be used for drinking, cooking, washing, cleaning, bathing, and showering based on the *inorganic chemical results only*, but aesthetic problems such as bad taste, odor, staining of porcelain, etc. may occur. You may want to install a household water treatment system to address aesthetic problems.

| | | | | | |
|-----------|----------|----------|----------|------|-----------|
| Barium | Cadmium | Chromium | Fluoride | Iron | Magnesium |
| Manganese | Selenium | Silver | pH | Zinc | |

For more information regarding your well water results, please call the North Carolina Division of Public Health at 919-707-5900.

The Environmental Protection Agency (EPA) considers Iron and Manganese as a secondary contaminant which means it does NOT have a direct impact on health.