

SITE/SI EVALUATION FOR ON-SI WASTEWATER

APPLICANT NAME _____

DATE _____

FACTORS		PROFILES													
		1	2	3	4	5	6	7	8	9	10				
LANDSCAPE POSITION	.1940														
SLOPE (%)	.1940														
HORIZON 1 DEPTH		0-12	0-10	0-11											
Texture Group	.1941(A)(1)	LS	LS	LS											
Consistence	.1941	Ufr	Ufr	Ufr											
Structure	.1941(A)(2)	G	G	G											
Mineralogy	.1941(A)(3)	UCS	UCS	UCS											
HORIZON 2 DEPTH		12-36	10-36	11-37											
Texture Group	.1941(A)(1)	S:C	C	C											
Consistence	.1941	F	F	F											
Structure	.1941(A)(2)	SBK	SBK	SBK											
Mineralogy	.1941(A)(3)	SCS	SCS	SCS											
HORIZON 3 DEPTH															
Texture Group	.1941(A)(1)														
Consistence	.1941														
Structure	.1941(A)(2)														
Mineralogy	.1941(A)(3)														
HORIZON 4 DEPTH															
Texture Group	.1941(A)(1)														
Consistence	.1941														
Structure	.1941(A)(2)														
Mineralogy	.1941(A)(3)														
SOIL WETNESS	.1942														
RESTRICTIVE HORIZON	.1944														
SAPROLITE	.1943/.1956														
CLASSIFICATION	.1948	PS	PS	PS											
LONG TERM ACCEPTANCE RATE	.1955	.35	.3	.7											

