

01-5-2903

LARNETT COUNTY HEALTH DEPARTMENT ENVIRONMENTAL HEALTH DIVISION

No 13404

OPERATIONS PERMIT

Name: (owner) Brandon Lee☒ New Installation☒ Septic TankProperty Location: SR# Salt Market 1774☐ Repairs☒ Nitrification Line

Subdivision _____

Lot # _____

TAX ID# _____

Quadrant # _____

Contractor: Basefoot Septic

Registration # _____

Basement with Plumbing: ☐Garage: ☐Water Supply: ☒ Well ☒ Public☐ CommunityDistance From Well: 50' ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: ☒ Conventional☐ Other _____Size of tank: Septic Tank: 1000 gallons

Pump Tank: _____ gallons

Subsurface No. of exact length width of depth of
Drainage Field ditches 2 of each ditch 175 ft. ditches 3 ft. ditches 18-24 in.

French Drain: _____ Linear feet

Date: 10-4-01PERMIT NO. 18492

Inspected by: James E. Markant
Environmental Health Specialist

