SITE/S . EVALUATION FOR ON-S WASTEWATER

APPLICANT NAME _____ *DATE* _____

FACTORS		PROFILES									
		1	2	3	4	5	6	7	8	9	1
LANDSCAPE POSITION	.1940	L	L								
SLOPE (%)	.1940	2	2								
HORIZON 1 DEPTH		0-12	0-12								
Texture Group	.1941(A)(1)	SL	SL								
Consistence	.1941	PL	PL								
Structure	.1941(A)(2)	GR	GR								
Mineralogy	.1941(A)(3)	NSNP	NSNP								
HORIZON 2 DEPTH		12-18	12-18								
Texture Group	.1941(A)(1)	SCL	SCL								
Consistence	.1941	PL	PL								
Structure	.1941(A)(2)	GR	GR								
Mineralogy	.1941(A)(3)	SSSP	SSSP								
HORIZON 3 DEPTH		18-36	18-36								
Texture Group	.1941(A)(1)	SC-CL	SC CL								
Consistence	.1941	SL PLN	SL PL								
Structure	.1941(A)(2)	PRISM	PRISM								
Mineralogy	.1941(A)(3)	SSSP	SSSP								
HORIZON 4 DEPTH											
Texture Group	.1941(A)(1)										
Consistence	.1941										
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
SOIL WETNESS	.1942	36cm	36cm								
RESTRICTIVE HORIZON	.1944										
SAPROLITE	.1943/.1956										
CLASSIFICATION	.1948										
LONG TERM ACCEPTANCE RATE	.1955	.14	.35								