

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Russell Lamm Const New Installation Septic Tank
 Property Location: SR# Hwy 55 Repairs Nitrification Line

Subdivision BRAXTON Lot # 17

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 3 Lot Size: 32,253 sq ft

Basement with Plumbing: Garage:
 Water Supply: Well Public Community
 Distance From Well: 50' ft.


Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____
 Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons
 Subsurface Drainage Field No. of ditches 2 exact length 150 ft. width of ditches 3 ft. depth of ditches 20 → 12 in.
 French Drain Required: _____ Linear feet

This permit is subject to revocation if site plans or intended use change.

Date: 7-30-02
 Signed: James E. Markant
 Environmental Health Specialist

** Maintain all Setbacks*
** START DITCHES AT 20" DEEP*
THEY SHOULD BE WORKED TO 12" ON LAST LINE. Soil WILL BE NEEDED TO COVER LAST Section also!



HARNETT COUNTY HEALTH DEPARTMENT
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department, Improvement Permit # 13939. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. This authorization will be invalid if ownership, site plans, or intended use change.

Russell Lamm Const 919-894-5517
Name Telephone #

488 Johnson Rd Coats N.C. 27521
Address

Hwy 55 55
Property Location SR# Road Name

BRAXTON 17 3 32,253 sq ft →
Subdivision Lot # # Bedrooms Proposed Lot size

TYPE OF SYSTEM

New Installation Repair Septic Tank Nitrification Lines
 Conventional Other _____ Basement With Plumbing Without Plumbing

Water Supply: Well Public - Minimum Well Setback: _____ Ft.
Septic Tank 1000 Pump Chamber _____

NITRIFICATION FIELD SPECIFICATIONS

Number of fields 2 # of lines per field 2 Length of lines 150 Ft.

Width of ditches 3 ft. Depth of ditches 20-212 inches

French Drain: Linear feet required _____ Depth of gravel _____

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.

James E. Markant 7-30-02
Signature of Authorized Agent for Harnett County Date