

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner: _____
 Address: _____
 Proposed Facility: _____ Design Flow (.1949): _____
 Location of Site: _____
 Water Supply: Public Individual Well
 Evaluation Method: Auger Boring Pit
 Type of Wastewater: Sewage Industrial Process

Applicant: _____
 Date Evaluated: _____
 Property Size: _____
 Property Recorded: _____
 Spring Other
 Cut
 Mixed

Profile #	1940 Landscape Position/Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			1941 Structure/Texture	1941 Consistence Mineralogy	1942 Soil Wetness/Color	1943 Soil Depth (IN.)	1956 Sapro Class	1944 Restr. Horiz	
1	L 2%	0-24	SL	FR GN NSNP					4
		24-48	SCL	SUBM 1 5/8" SS.P	42	7.54			
2	L 2%	0-26	SL	FR GN NSNP					4
		26-48	SCL	SUBM 1 5/8" SS.P	44	7.54			
3	L 2%	0-16	SL	FR GN NSNP					-4-35
		10-40	SCL	SUBM 1 5/8" SS.P	36	7.54			

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	25%	25% 60
Site LTAR	4	4

Other Factors (.1946): _____
 Site Classification (.1948): _____
 Evaluated By: _____
 Others Present: _____


COMMENTS: _____

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	NS-NON-STICKY SS-SLIGHTLY STICKY S-STICKY VS-VERY STICKY NP-NON-PLASTIC SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6		
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE	III	SI-SILT-	0.6 - 0.3		
H-HEAD SLOPE		SIL-SILT LOAM			
CC-CONCLAVE SLOPE		CL-CLAY LOAM			
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			
T-TERRACE		SICL-SILTY CLAY LOAM			
FP-FLOOD PLAN	IV	SIC-SILTY CLAY	0.4 - 0.1		
		C-CLAY			
		SC-SANDY CLAY			

STRUCTURE
 SG-SINGLE GRAIN
 M-MASSIVE
 CR-CRUMB
 GR-GRANULAR
 SBK-SUBANGULAR BLOCKY
 ABK-ANGULAR BLOCKY
 PL-PLATY
 PR-PRISMATIC

MINERALOGY
 SLIGHTLY EXPANSIVE
 EXPANSIVE


Show profile locations and other site features (dimensions, reference or benchmark, and North).



SRB-----Set Rebar
 R/W-----Right of Way
 C-----Centerline
 PNE-----Point Not Established
 FRRS-----Found Railroad Spike

NOTE: All measurements shown are horizontal ground measurements unless otherwise noted.

Area computed by coordinates.



A.B. Parker Jr.

7.21 acres ±
 (By Deduction)

John A. Parker Sr.
 Deed Book 1574, Page 69-73

Dianne Parker Barefoot
 Deed Book 1376, Page 827

Shel