

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: _____
 Address: _____
 Proposed Facility: _____ Design Flow (.1949): _____
 Location of Site: _____
 Water Supply: Public Individual Well
 Evaluation Method: Auger Boring Pit
 Type of Wastewater: Sewage Industrial Process

Applicant: _____
 Date Evaluated: 5/9/07
 Property Size: _____
 Property Recorded: _____
 Spring Other

P R O F I L E #	1940 Landscape Position/ Slope%	SOIL MORPHOLOGY 1941			OTHER PROFILE FACTORS				Profile Class & LTAR
		Horizon Depth (IN.)	1941 Structure/ Texture	1941 Consistence Mineralogy	1942 Soil Wetness/ Color	1943 Soil Depth (IN.)	1944 Saprot Class	1945 Restr. Horiz.	
	39 LS	0-36	G/SH	VF MS NP					PS-8
		36+	SBK/C	F. SSP	10YR 8/1 @ 96"				
		G-14	0-14	G/SH	VF MS NP				25/PS-3
			14-25	SBK/C	F. SP	10YR 8/1 @ 25"			
		G-18	0-18	G/LS	VF MS NP				PS-4 45"
			18-46	SBK/SC1	F. SSP				
		G-10	0-10	G/LS	VF MS NP				PS-3
			10-36	SBK/SC1	F. SP	10YR 8/1 @ 35"			
		G-15	0-15	G/LS	VF MS NP				PS-3
			15-32	SBK/C	F. SP	10YR 8/1 @ 32"			

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	Accepted	pump to Acceptor
Site LTAR	.3	.3

Other Factors (.1946): Site plan needs to be reviewed
 Site Classification (.1948): PS
 Evaluated By: DM
 Others Present: OT