

HTE# 08-5-19250

# Harrison County Department of Public Health

24444

## Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: MAURO + VIRGINIA CONTRERAS PROPERTY LOCATION: HWY 55  
 NEW  REPAIR  EXPANSION  SUBDIVISION: BRAXTON LOT # 912  
 Site Improvements required prior to Construction Authorization Issuance:

Type of Structure: SFD  
 Proposed Wastewater System Type: 25% REDUCED SYSTEM  
 Projected Daily Flow: 480 GPD  
 Number of bedrooms: 4 Number of Occupants: 8 max  
 Basement  Yes  No  
 Pump Required:  Yes  No  May be required based on final location and elevations of facilities  
 Type of Water Supply:  Community  Public  Well Distance from well \_\_\_\_\_ feet Permit valid for:  Five years  
 No expiration  
 Permit conditions: \_\_\_\_\_

Authorized State Agent: James E. Mahan Date: 2-6-08 SEE ATTACHED SITE SKETCH  
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

## Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: MAURO + VIRGINIA CONTRERAS PROPERTY LOCATION: HWY 55  
 SUBDIVISION: BRAXTON LOT # 912

Facility Type: SFD  New  Expansion  Repair  
 Basement?  Yes  No Basement Fixtures?  Yes  No  
 Type of Wastewater System\*\* 25% REDUCED SYSTEM (Initial) Wastewater Flow: 480 GPD  
 (See note below, if applicable   
25% REDUCED SYSTEM (Repair)

### Installation Requirements/Conditions

Septic Tank Size 1200 gallons Exact length of each trench 4x 100 feet Trench Spacing: 9 Feet on Center  
 Pump Tank Size \_\_\_\_\_ gallons Trenches shall be installed on contour at a Soil Cover: 6 inches  
 Maximum Trench Depth of: 22" inches (Maximum soil cover shall not exceed  
 (Trench bottoms shall be level to  $\pm 1/4"$  36" above the trench bottom)  
 in all directions)  
 Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM Aggregate Depth: 6 inches below pipe  
2 inches above pipe  
 Conditions: \_\_\_\_\_ 12 inches total

\*\*If applicable: *I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.*

Owner/Legal Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: James E. Mahan Date: 2-6-08 SEE ATTACHED SITE SKETCH  
 Construction Authorization Expiration Date: 2-6-13

HTE# 08-5-19250

Permit # 24444

# Harnett County Department of Public Health Site Sketch

ISSUED TO: MAURO + VIRGINIA CONTRERAS PROPERTY LOCATOR: HWY 55  
SUBDIVISION: BRAXTON LOT # 9C

Authorized State Agent: James E. Manhart Date: 2-5-08

