

**SOIL/SITE EVALUATION  
for ON-SITE WASTEWATER SYSTEM**

Owner:  
Address:  
Proposed Facility: SFA Design Flow (.1949): 480 to 2  
Location of Site: 300  
Water Supply:  Public  Individual  Well  
Evaluation Method:  Auger Boring  Pit  
Type of Wastewater:  Sewage  Industrial Process

Applicant:  
Date Evaluated: 9-19-08  
Property Size:  
Property Recorded:  
 Spring  Other  
 Cut  
 Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L 6%	0-18	SL	PL GR NSNP	oil between				.45 LTAR
		18-40	SCL	PL GR NSNP	24" - 36"				
2	L	0-18	SL	PL GR NSNP	30" OT				.3 LTAR
		18-40	SCL	PL GR NSNP	24"				
3	L 7%	0-24	SL	PL GR NSNP	12" to water				.3 LTAR
4	5%			Clayey Soils	5" water				
5	5%				5" water				
6	5 1/2%				5" water				
7	5 1/2%				8" water				.3 LTAR
8	L 5%	0-18	SL	PL GR NSNP	12" water				.3 LTAR
		18-36	SCL	PL GR NSNP	24" OT				

Description	Initial System	Repair System
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
System Type(s)	75%	CON AT GRADE 12" man
Site LTAR	.3	.3

Other Factors (.1946): \_\_\_\_\_  
Site Classification (.1948): R.S  
Evaluated By: [Signature]  
Others Present: [Signature]