

**SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM**

Owner:
Address:
Proposed Facility: *SPT 6000* Design Flow (.1949): *480*
Location of Site:
Water Supply: Public Individual Well
Evaluation Method: Auger Boring Pit
Type of Wastewater: Sewage Industrial Process

Applicant: *21639*
Date Evaluated: *3-9-10 #1-09*
Property Size:
Property Recorded:
 Spring Other
 Cut
 Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro. Class	.1944 Restr. Horiz.	
<i>2,3 3,5,6</i>	<i>L 3%</i>	<i>0-20</i>	<i>SL</i>	<i>WET and glyde soil at surface</i>					
<i>7</i>	<i>L 4%</i>	<i>0-16</i>	<i>SL</i>	<i>FL GR W&NP</i>					
		<i>16-28</i>	<i>SCL</i>	<i>WET Firm / S&P WET</i>	<i>23"-24" 1.5% 1.2</i>				<i>.2</i>
<i>9,10 11,12,13</i>	<i>L 6%</i>	<i>0-16</i>	<i>SL</i>	<i>set AT surface</i>					
		<i>16-30</i>	<i>SCL</i>	<i>and throughout</i>					
<i>14</i>	<i>L 7%</i>	<i>0-34</i>	<i>SL</i>	<i>FL GR W&NP</i>					
		<i>34-48</i>	<i>SCL</i>	<i>Firm / S&P S.P.</i>	<i>44" 1.5% 1.2</i>				<i>.35-.4</i>
<i>15</i>	<i>L 7%</i>	<i>0-20</i>	<i>SL</i>	<i>FL GR W&NP</i>					
		<i>20-46</i>	<i>SC-CIM</i>	<i>Firm / S&P S.P.</i>	<i>42" 1.5% 1.2</i>				<i>.35</i>

Description	Initial System	Repair System
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
System Type(s)	<i>2500</i>	<i>2500</i>
Site LTAR	<i>.35</i>	<i>.35-.2</i>

Other Factors (.1946): _____
Site Classification (.1948): *PS*
Evaluated By: *John + DT*
Others Present: