## HTE# 09-5-22071 Harnest County Department of Public mealth

25405

## Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: S/21769 011) STACE PLAS ISSUED TO: JUSTEN PODE SUBDIVISION Perventant Estates EXPANSION Site Improvements required prior to Construction Authorization Issuance: Type of Structure: BOD 25% RESURTED Proposed Wastewater System Type: Projected Daily Flow: 360 Number of bedrooms: \_\_\_\_\_\_ Number of Occupants: \_\_\_\_\_\_ max Basement Yes May be required based on final location and elevations of facilities Pump Required: Yes No Type of Water Supply: 

Community Public Well Distance from well feet Permit valid for: ■ No expiration Permit conditions: SEE ATTACHED SITE SKETCH The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.. **Construction Authorization** (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: JUSTEN POPE SUBDIVISION REVERTIONS ESTAGE RD

LOT # 16 SUBDIVISION Tavaslund

New Expansion 
Repair O (Initial) Wastewater Flow: 360 GPD Type of Wastewater System\*\* 25% REDUCTION Susten (See note below, if applicable 

) Number of trenches 3

Exact length of each trench 80 feet Trench Spacing: 7 Feet on Center inches

Soil Cover: 6 inches Installation Requirements/Conditions Septic Tank Size 1000 gallons Pump Tank Size gallons Maximum Trench Depth of: Zy inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) 6 inches below pipe Pump Requirements: \_\_\_\_\_\_ft. TDH vs. \_\_\_\_\_ Aggregate Depth: 2 inches above pipe \*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This SEE ATTACHED SITE SKETCH Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Authorized State Agent: Jams & Manhantons -Date: 5-21-09 Construction Authorization Expiration Date: 5-21-14

## Harnett County Department of Public Health Site Sketch

