

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:

Address: SFD

Date Evaluated: 3/5/11

Design Flow (.1949): 360

Property Size:

Location of Site:

Property Recorded:

Water Supply:

Public

Individual

Well ^{with 100'}

Spring

Other

Evaluation Method:

Auger Boring

Pit

Cut

Type of Wastewater:

Sewage

Industrial Process

Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (in.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Minerology	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1936 Sapro Class	.1944 Restr Horiz.	
1	L-2%	0-15	Loam	FL 6A NSIP					
		15-36	Clay	FL M 7K S.P.	30-32" 7.5/2				3
2	L 2%	0-16	Loam	FL 6A NSIP					
		16-36	Clay	FL M 7K S.P.	30-32" 7.5/2				3
3	L 3%	0-8	Loam	FL 6A NSIP					
		8-36	Clay	FL M 7K S.P.	28" 7.5/2				3
4	L 2.5%	0-8	Loam	FL 6A NSIP					
		8-36	Clay	FL M 7K S.P.	28" 7.5/2				3

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): P3 Evaluated By: JW Others Present:
Available Space (.1945)			
System Type(s)	250	250	
Site LTAR	3	3	