HTE# 11-5-27499

Harnett county Department of Public Hearth

Improvement Permit

26532


A building permit cannot be issued with only an Improvement Permit SUBDIVISION ONKINALES PROPERTY LOCATION: Elm-57 Site Improvements required prior to Construction Authorization Issuance: NEW SFD Type of Structure: Proposed Wastewater System Type: Ex Syste Projected Daily Flow: 360 Number of bedrooms: 3 Number of Occupants: 6 max Basement Yes ☐ No May be required based on final location and elevations of facilities Pump Required: ☐Yes Type of Water Supply:

Community Public

Well Distance from well Permit valid for: Five years □ No expiration SEE ATTACHED SITE SKETCH Authorized State Agent:: The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. Facility Type: ______ | New | SupplyISION | OAKDAIG | LOT # 4 ISSUED TO: DANNY Mcland PROPERTY LOCATION: KIN-55 (Initial) Wastewater Flow: 360 GPD Type of Wastewater System** EXESTENY System (See note below, if applicable □) Installation Requirements/Conditions Septic Tank Size 1000 Exact length of each trench Trench Spacing: Feet on Center gallons Pump Tank Size _____ gallons Trenches shall be installed on contour at a Soil Cover: Maximum Trench Depth of: ______ inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: _____ft. TDH vs. ____ inches below pipe Aggregate Depth: ______ inches above pipe TANK Replacament inches total WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. **If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This SEE ATTACHED SITE SKETCH Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Authorized State Agent: Construction Authorization Expiration Date: 9 78-76

Harnett County Department of Public Health Site Sketch

ISSUED TO: DANNY Mcland		DAKDAG		LOT # # 5
Authorized State Agent: James Mashan	forous	Date:	9-25-11	
V		*NEW TA	NK TO BE	SET
		5'offor Recon	FUSW Home to ?	1-130x.



57 1873 CANNOLL Byrd W