

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant: Hughes
 Address: Date Evaluated:
 Proposed Facility: SFD Design Flow (.1949): 360 Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1,2	L-22	0-18	SL						
		18-40	SL		36-38	2.5g 31			.4
3	L-32	0-12	SL						
		12-25	SL-CLAY		20-22	1.5g 31			.2
4	L-33	0-18	CLAY uact	Glyede					
5	L	0-15	SL						
		15-36	SL-CLAY CLAY		30-32	1.5g 31			.35-.4

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948) Evaluated By: <u>[Signature]</u> Others Present:
Available Space (.1945)			
System Type(s)	20"	20"	
Site LTAR	-4	-4	