

HTE# 16-5-38167

HARNETT COUNTY HEALTH DEPARTMENT  
ENVIRONMENTAL HEALTH  
307 CORNELIUS HARNETT BOULEVARD  
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME STEVEN DAVIDS PHONE # 910-635-9422

ADDRESS 150 Woods Pond Lane DUNN N.C. 28334

NAME OF MOBILE HOME PARK OR S/D \_\_\_\_\_

NAME OF OWNER (IF DIFFERENT) \_\_\_\_\_

ADDRESS OF OWNER (IF DIFFERENT) \_\_\_\_\_

PROPERTY LOCATION: STATE ROAD NAME AND # 201705 Old Frogpond Rd

**PURPOSE OF INSPECTION:** 30730 From Skop

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

**THIS INSPECTION IS VOID IF:**

- (1) the intended use of the septic system should change, and/or
- (2) the system should fail or malfunction, and/or
- (3) the owner or tenant of the property changes, and/or
- (4) after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM  
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

James E. Montague  
Signature of Environmental Health Specialist

3-18-16  
Date