

ADDRESS : 130 WOODMILL LN SUBDIV:
CONTRACTOR : PHONE :
OWNER : T2 FARMS LLC PHONE :
PARCEL : 08-0653- - -0050- - -
APPL NUMBER: 17-50042637 CP FARM BUILDING/ETC.
APPL NOTES : BPMN 12/18/17 T/S: 12/18/2017 08:15 AM BPETRICH --
THIS CUSTOMER IS FARM EXEMPT - ORIG
WANTED TO PURCHASE A BLDG PERMIT SO HE
COULD GET A CO ON THIS FARM OFFICE AND
MAKE IT EASIER TO CHANGE USE TO A DIFF
BUSINESS IN A FEW YEARS. CUSTOMER CHGED
MIND AS HE DIDN'T WANT TO GO THROUGH
PLANNING/FIRE MARSHALL/PUBLIC UTILITES
AS A COMMERCIAL BUILDING AT THIS TIME.
HE PURCHASED THIS AS FARM EXEMPT & WILL
GO THROUGH DRB AND MAKE ANY UPGRADES IN

STRUCTURE: 000 000 30X100 OFFICE - RESIDENTIAL USE ONLY

FLOOD ZONE : FLOOD ZONE X
PROPOSED USE : FARM OFFICE SEPTIC - EXISTING? : NEW
WATER SUPPLY : COUNTY

PERMIT: CPEC 00 CP ELECTRICAL COMMERCIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E251 01	2/12/18 2/12/18	MC AP	C*ELEC ROUGH IN TIME: 17:00 VRU #: 003087608 T/S: 02/08/2018 02:49 PM BPETRICH T/S: 02/12/2018 03:57 PM MCOOK
E267 01	2/12/18 2/12/18	MC DA	C*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 003087582 T/S: 02/08/2018 02:48 PM BPETRICH T/S: 02/12/2018 12:49 PM MCOOK 1. MISSING NAIL PLATES (MARKED IN BLUE) 2. NEED PREMISE NUMBER FOR T-POLE 3. INSTALL F/D STOP THRU-OUT
E253 01	5/01/18 5/01/18	MC AP	C*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 003120797 T/S: 04/30/2018 10:25 AM JBROCK T/S: 05/01/2018 03:41 PM MCOOK 1. called in at 1:50pm
E265 01	6/22/18 <u>11</u>	TI <u>AP</u>	C*ELEC FINAL TIME: 17:00 VRU #: 003143039 T/S: 06/20/2018 03:43 PM BPETRICH

PERMIT: CPMC 00 CP MECHANICAL COMMERCIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
M459 01	2/12/18 2/12/18	MC DA	C*MECH ROUGH IN TIME: 17:00 VRU #: 003087616 T/S: 02/08/2018 02:49 PM BPETRICH T/S: 02/12/2018 12:51 PM MCOOK 1. INSTALL F/D STOP THRU-OUT
M459 02	2/21/18 2/21/18	BS AP	C*MECH ROUGH IN TIME: 17:00 VRU #: 003091733 T/S: 02/20/2018 08:51 AM BPETRICH T/S: February 21, 2018 07:01 PM BSUTTON Rough ins approved. Firestop was completed also
M465 01	6/22/18 <u>11</u>	TI <u>AP</u>	C*MECH FINAL TIME: 17:00 VRU #: 003143047 T/S: 06/20/2018 03:43 PM BPETRICH

PERMIT: CPPC 00 CP PLUMBING COMMERCIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
--------	---------------------	-------------	------------------------------

ADDRESS . : 130 WOODMILL LN SUBDIV:
 CONTRACTOR : PHONE :
 OWNER . . : T2 FARMS LLC PHONE :
 PARCEL . . : 08-0653- - -0050- - -
 APPL NUMBER: 17-50042637 CP FARM BUILDING/ETC.

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P357 01	12/29/17	MC	C*PLUMB UNDER SLAB VRU #: 003071071
	12/29/17	AP	T/S: 12/29/2017 02:44 PM MCOOK -----
P351 01	2/12/18	MC	C*PLUMB ROUGH IN TIME: 17:00 VRU #: 003087624
	2/12/18	DA	T/S: 02/08/2018 02:49 PM BPETRICH ----- T/S: 02/12/2018 12:51 PM MCOOK ----- 1. NO AIR TEST (GAUGE BROKE) 2. MIN. 1- 2 INCH VENT MUST BE CONTINUOUS THRU ROOF3. INSTALL F/D STOP THRU-OUT
P351 02	2/21/18	BS	C*PLUMB ROUGH IN TIME: 17:00 VRU #: 003091741
	2/21/18	AP	T/S: 02/20/2018 08:52 AM BPETRICH ----- T/S: February 21, 2018 07:01 PM BSUTTON ----- Rough ins approved. Firestop was completed also
P353 01	6/18/18	MC	C*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 003141025
	6/18/18	AP	T/S: 06/15/2018 11:13 AM BPETRICH ----- T/S: 06/18/2018 03:09 PM MCOOK -----
P355 01	6/18/18	MC	C*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 003141017
	6/18/18	AP	T/S: 06/15/2018 11:13 AM BPETRICH ----- T/S: 06/18/2018 03:09 PM MCOOK -----
P361 01	6/22/18	TI	C*PLUMB FINAL TIME: 17:00 VRU #: 003143054
	<u>11</u>	<u>AP</u>	T/S: 06/20/2018 03:43 PM BPETRICH -----

COMMENTS AND NOTES