## HTE# 18-5-43277 Harnett County Department of Public Health

29910

## Improvement Permit

A building permit cann	not be issued with only an Improvement Permit	- N
	PROPERTY LOCATION: 5. Lincoln St. (	Sa 1700)
ISSUED TO: Christic Ross	SUBDIVISION	LOT #
NEW REPAIR EXPANSION	Site Improvements required prior to Construction Aut	horization Issuance:
Type of Structure: Pole Barn - Farm Use		
Proposed Wastewater System Type: CONV. OR 2590 red	Sys.	
Projected Daily Flow: GPD		
Number of bedrooms: <u>NA</u> Number of Occupants: <u>NA</u>	_max	
Basement Yes INO		
Pump Required: Yes YNO May be required based on final lo	ocation and elevations of facilities	a contra Materia and contra Marco and Barry
	ce from well 100 feet (MIN) Permit valid for:	Five years
Permit conditions: 240 GPD Requested County Water OR Welf - 10	d by Applicant	No expiration
County water on well - 10	off well setback Reg.	1 red
	l	
Authorized State Agent	13100 03/0G 10010 mm	

## **Construction** Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Christi	C ROSS	PROPERTY LOCATION:	Do Lincoln St.	(SR 1700)
		SUBDIVISION		LOT #
Facility Type: 1010 Basa	-room Us	🗲 🖬 New 🔲 Expansion 🔲 Repa	air	
Basement? 🗌 Yes 🗳 No	Basement Fixtu	res? 🗆 Yes 🗆 No		
Type of Wastewater System**	Conventio	nal OR 25% red. 5%	≤ - (Initial) Wastewater Flow:	240 GPD
(See note below, if applicable 🔲	)	b		
(	Convention	) on 25% red. (Repair)		
Installation Requirements/Condition	ns	Number of trenches 3	0	
Septic Tank Size 1000	gallons	Exact length of each trench $\underline{-70}$ feet	: Trench Spacing:9	Feet on Center
Pump Tank Size	gallons	Trenches shall be installed on contour at a	Soil Cover: 12	
		Maximum Trench Depth of: <u>24</u> inche	es (Maximum soil cover shall i	not exceed
		(Trench bottoms shall be level to $+/-1/4$ "	36" above the trench both	tom)
		in all directions)		<i>.</i>
Pump Requirements:	_ft. TDH vs	GPM	_NA	inches below pipe
			Aggregate Depth:	A inches above pipe
Conditions:			<u></u>	inches total

## WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.					
Owner/Legal Representative Signature:	Date:				
This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This					
Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal		SEE ATTACHED SITE SKETCH			
Authorized State Agent:	Date: 03 /08 /	2018			
ANTRENS CURRIN Construction Authorization					

