

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: _____ Applicant: _____ Date Evaluated: _____
 Address: _____ Design Flow (.1949): 100 gpd Property Size: _____
 Proposed Facility: _____ Property Recorded: _____
 Location of Site: _____
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1		0-12	G LS	very fine					
		12-27	SBK C	fn s/sp	10YR 7/2 R 2.2				PS .41
2		0-12	G 2S	very fine					
		12-38	SBK C	fn s/sp	10YR 7/2 R 3.7				PS .41
3		0-12	G 2S	very fine					
		12-26	SBK C	fn s/sp	10YR 7/2 R 2.6				PS .41

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: CX Others Present: -
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
System Type(s)	CONVENTIONAL		
Site LTAR	12	12	