


COMMENTS: _____

LANDSCAPE POSITIONS	GROUP	TEXTURES	.1955 LTAR	CONSISTENCE MOIST	WET
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE	NS-NON-STICKY
S-SHOULDER SLOPE		LS-LOAMY SAND		FR-FRIABLE	SS-SLIGHTLY STICKY
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FI-FIRM	S-STICKY
FS-FOOT SLOPE		L-LOAM		VFI-VERY FIRM	VS-VERY STICKY
N-NOSE SLOPE	III	SI-SILT-	0.6 - 0.3	EFI-EXTREMELY FIRM	NP-NON-PLASTIC
H-HEAD SLOPE		SIL-SILT LOAM		SP-SLIGHTLY STICKY	
CC-CONCLAVE SLOPE		CL-CLAY LOAM		P-PLASTIC	
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM		VP-VERY PLASTIC	
T-TERRACE	IV	SIC-SILTY CLAY	0.4 - 0.1		
FP-FLOOD PLAN		C-CLAY			
		SC-SANDY CLAY			

STRUCTURE
 SG-SINGLE GRAIN
 M-MASSIVE
 CR-CRUMB
 GR-GRANULAR
 SBK-SUBANGULAR BLOCKY
 ABK-ANGULAR BLOCKY
 PL-PLATY
 PR-PRISMATIC

MINERALOGY
 SLIGHTLY EXPANSIVE
 EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).




SITE/SOIL VALUATION FOR ON-SITE WASTEWATER

APPLICANT NAME _____

DATE _____

FACTORS		PROFILES													
		1	2	3	4	5	6	7	8	9	10				
LANDSCAPE POSITION	.1940														
SLOPE (%)	.1940														
HORIZON 1 DEPTH		0-33	0-26	0-32"	0-25"	0-34	0-44"	0-30							
Texture Group	.1941(A)(1)	SL	SL	SL	SL	SL	SL	SL							
Consistence	.1941	VFR	VFR		VFR			VFR							
Structure	.1941(A)(2)	G	G		G			G							
Mineralogy	.1941(A)(3)	NS/NP	NS/NP		NS/NP			NS/NP							
HORIZON 2 DEPTH		33"+	26-36"	32"-40"	25-41"	34-42"	44"+	30-41"							
Texture Group	.1941(A)(1)	C	SCL	SCL*	SCL*	SCL	SCL	SCL							
Consistence	.1941	F	FR	FR	FR	FR	FR	FR							
Structure	.1941(A)(2)	SBK	SBK	SBK	SBK	SBK	SBK	SBK							
Mineralogy	.1941(A)(3)	S/SP	S/SP	S/SP	S/SP	S/SP	S/SP	S/SP							
HORIZON 3 DEPTH			36"	40"+		42"+		41"+							
Texture Group	.1941(A)(1)		PM	PM		PM		PM							
Consistence	.1941														
Structure	.1941(A)(2)														
Mineralogy	.1941(A)(3)														
HORIZON 4 DEPTH															
Texture Group	.1941(A)(1)														
Consistence	.1941														
Structure	.1941(A)(2)														
Mineralogy	.1941(A)(3)														
SOIL WETNESS	.1942		38"	40	41"	42"		41"							
RESTRICTIVE HORIZON	.1944														
SAPROLITE	.1943/.1956														
CLASSIFICATION	.1948	PS	PS	PS	PS	PS	PS	PS							
LONG TERM ACCEPTANCE RATE	.1955		.45	.45	.45	.45	.8	.45							




SITE/SOIL VALUATION FOR ON-SITE WASTEWATER

APPLICANT NAME _____

DATE _____

FACTORS		PROFILES									
		1	2	3	4	5	6	7	8	9	10
LANDSCAPE POSITION	.1940				H ₂ O IN PIT						
SLOPE (%)	.1940										
HORIZON 1 DEPTH		0-33	0-24	0-17	0-21	0-20"	0-14	0-42"	0-16"		0-43"
Texture Group	.1941(A)(1)	SL	SL	SL	SL	SL	SL	C	SL		SL
Consistence	.1941	VFR	VFR	VFR		VFR	VFR	FI	VFR		VFR
Structure	.1941(A)(2)	G	G	G		G	G	SBK/M	G		G
Mineralogy	.1941(A)(3)	NS/NP	NS/NP	NS/NP		NS/NP	NS/NP	S/P	NS/NP		NS/NP
HORIZON 2 DEPTH		33-48"	24-31	17-29	21"-37"	20" +	14-19		16" +		43" +
Texture Group	.1941(A)(1)	C	SCL	SCL	SCL		SC/SCL		C		SC
Consistence	.1941	FR	FR	FR	F		FR/F		FI		F
Structure	.1941(A)(2)	SBK	SBK	SBK	SBK		SBK		M		SBK
Mineralogy	.1941(A)(3)	S/P	S/P	S/SC	S/P		S/P				SS/SP
HORIZON 3 DEPTH			31"	29" +	37" +		19"				
Texture Group	.1941(A)(1)		C	C	C		C				
Consistence	.1941		VFI	FI	FI		FI				
Structure	.1941(A)(2)		ABK	ABK	ABK		SBK				
Mineralogy	.1941(A)(3)		VS/VP	VS/VP	VS/VP		S/P				
HORIZON 4 DEPTH											
Texture Group	.1941(A)(1)										
Consistence	.1941										
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
SOIL WETNESS	.1942	44"	33"	21"		20	23"	4"	20"		
RESTRICTIVE HORIZON	.1944										
SAPROLITE	.1943/.1956										
CLASSIFICATION	.1948	PS	PS	US	PS	US	US	US	US		PS
LONG TERM ACCEPTANCE RATE	.1955	.3	.3		.3						.8



SITE/SOIL VALUATION FOR ON-SITE WASTEWATER

APPLICANT NAME _____

DATE _____

FACTORS		PROFILES									
		1	2	3	4	5	6	7	8	9	10
LANDSCAPE POSITION	.1940										
SLOPE (%)	.1940						*				
HORIZON 1 DEPTH		0-20	0-25	0-30	0-36	0-36	0-33	0-33	0-32	0-38"	0-27
Texture Group	.1941(A)(1)	SL	SL	SL	SL	SL	SL	SL	SL	SL	SL
Consistence	.1941	VK	VFR	VFR	VFR	VFR				VFR	
Structure	.1941(A)(2)	G	G	G	C	C				G	
Mineralogy	.1941(A)(3)	NS/NP	NS/NP	NS/NP	NS/NP	NS/NP				NS/NP	
HORIZON 2 DEPTH		20-40	25-42"	30-43"	36-45"	36-48"	38-43	33-37	32-34	38" r	27-37
Texture Group	.1941(A)(1)	SCL	SCL	SCL	SCL	SCL ⁺	SCL	SCL	SCL	SCL	SCL
Consistence	.1941	S/P	FR	FR	FR	FR	FR	FR	FR	FR	FR
Structure	.1941(A)(2)	SBK	SBK	SBK	SBK	SBK	SBK	SBK	SBK	SBK	SBK
Mineralogy	.1941(A)(3)	S/P	S/SP	S/SP	S/SP	S/SP	S/P	S/SP	S/SP	S/SP	S/SP
HORIZON 3 DEPTH		5/SP					43-48	37" r	34"		37"
Texture Group	.1941(A)(1)					DISTINCT BOUNDARY	C	C	C		C
Consistence	.1941					SOIL BOUNDARY	FR	FR	FR		F
Structure	.1941(A)(2)					SOIL BOUNDARY	SBK	SBK	SBK		SBK/P
Mineralogy	.1941(A)(3)					36" r	S/P	S/P	S/P		S/VP
HORIZON 4 DEPTH											
Texture Group	.1941(A)(1)										
Consistence	.1941										
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
SOIL WETNESS	.1942	40"	40"	43"	43"	41"				47"	
RESTRICTIVE HORIZON	.1944										
SAPROLITE	.1943/.1956										
CLASSIFICATION	.1948	PS	PS	PS	PS	PS	PS	PS	PS	PS	PS
LONG TERM ACCEPTANCE RATE	.1955	.45			.8	.8	.45	.45	.4	.8	.45

Lot 1 Lot 2 Road 3 4 5 6 7

