

Improvement Permit

This permit replaces #22550 (3.22.06)

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Jeff Swire PROPERTY LOCATION: Hicks Rd
 NEW REPAIR EXPANSION SUBDIVISION: Weyerhaeuser LOT # 1
 Type of Structure: SFD-50x50-3BR Site Improvements required prior to Construction Authorization Issuance: 31.55 ac
 Proposed Wastewater System Type: Pump to at grade system Site #1
 Projected Daily Flow: 360 GPD Must Bring in 8 to 12" of approved
 Number of bedrooms: 3 Number of Occupants: 6 max cover.
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well 100 feet Permit valid for: Five years
 Permit conditions: meet onsite for final layout - if basement has plumbing No expiration
Pump will be required - maintain all set backs - keep tanks 15' from
Basement keep well 100' from any part of septic system
 Authorized State Agent: J. Swire Date: 4.29.08 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Jeff Swire PROPERTY LOCATION: Hicks Rd
 FACILITY TYPE: SFD-50x50-3BR New Expansion Repair Site 1 SUBDIVISION: Weyerhaeuser LOT # 1
 Basement? Yes No Basement Fixtures? Yes No 31.55 ac
 Type of Wastewater System** Pump to At grade (Initial) Wastewater Flow: 360 GPD
 (See note below, if applicable) LPP (Repair)

Installation Requirements/Conditions
 Septic Tank Size 1000 gallons Number of trenches 6
 Pump Tank Size 1000 gallons Exact length of each trench 100 feet Trench Spacing: 9 Feet on Center
 Trenches shall be installed on contour at a Soil Cover: 6 inches
 Maximum Trench Depth of: 12 max inches (Maximum soil cover shall not exceed
 (Trench bottoms shall be level to +/- 1/4" 36" above the trench bottom)
 in all directions)
 Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: 6 inches below pipe
2 inches above pipe
 Conditions: _____ 12 inches total

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: J. Swire Date: 04.29.08
 Construction Authorization Expiration Date: 04.27.2013

HTE# 03-500-8425 RR

Permit # 24765

Harnett County Department of Public Health Site Sketch

ISSUED TO: Jeff Swire PROPERTY LOCATOR: Hicks Rd
 SUBDIVISION: Weyerhaeuser LOT # 1
 Authorized State Agent: J. WARS Date: 4-23-08
 37.55 ac

SR 1266

Meet onsite for
 Final layout
 maintain all setbacks
 must bring in 8" to 12"
 of approved cover soil
 Final Plumbing stub out
 Depth will determine if
 a pump will be required
 or not.
 Final layout may change

