

Initial Application Date: 3/13/06

JW

Application # 0350008425R
1156518

Central Permitting 102 E. Front Street, Lillington, NC 27546 Phone: (910) 893-4759 Fax: (910) 893-2793 www.harnett.org

LANDOWNER: Weyerhaeuser Mailing Address: 800 Potomac Dr
City: Community State: NC Zip: 27817 Phone #:

APPLICANT: JEDD Swire Mailing Address: PO Box 312
City: High Springs Fuquay-Varina State: NC Zip: 27526 Phone #: 919-389-0312

PROPERTY LOCATION: SR #: 1264 SR Name: Hicks
Address: Hicks

Parcel: 13 6602 0034 PIN: 0612-71-3412 000

Zoning: B130 Subdivision: Weyerhaeuser Lot #: 1 Lot Size: 31.59

Flood Plain: X Panel: 15 Watershed: TL Deed Book/Page: 1720/157 Plat Book/Page: 200/1241

DIRECTIONS TO THE PROPERTY FROM LILLINGTON: 421 S to Cool Springs Rd (R) / (R) /
on Hicks Rd go 1 mile on Right.

PROPOSED USE:

SFD (Size 50 x 50) # Bedrooms 4 # Baths 3 Basement (w/wo bath) Garage Deck Crawl Space / Slab

Multi-Family Dwelling No. Units _____ No. Bedrooms/Unit _____

Manufactured Home (Size _____ x _____) # of Bedrooms _____ Garage _____ Deck _____

Number of persons per household 2

Business Sq. Ft. Retail Space _____ Type _____

Industry Sq. Ft. _____ Type _____

Church Seating Capacity _____ Kitchen _____

Home Occupation (Size _____ x _____) # Rooms _____ Use _____

Additional Information: _____

Accessory Building (Size _____ x _____) Use _____

Addition to Existing Building (Size _____ x _____) Use _____

Other _____

Additional Information: _____

Water Supply: County Well (No. dwellings _____) Other _____ Environmental Health Site Visit Date: _____

Sewage Supply: New Septic Tank Existing Septic Tank County Sewer Other _____

Erosion & Sedimentation Control Plan Required? YES NO

Property owner of this tract of land own land that contains a manufactured home w/in five hundred feet (500') of tract listed above? YES NO

Structures on this tract of land: Single family dwellings 1 proposed Manufactured homes _____ Other (specify) _____

Required Residential Property Line Setbacks:	Minimum	Actual
Front	35	<u>200/80</u>
Rear	25	<u>25+</u>
Side	10	<u>400</u>
Corner	20	<u>0</u>
Nearest Building	10	<u>0</u>

If permits are granted I agree to conform to all ordinances and the laws of the State of North Carolina regulating such work and the specifications or plans submitted. I hereby swear that the foregoing statements are accurate and correct to the best of my knowledge.

Signature of Owner or Owner's Agent _____ Date 3/13/06

This application expires 6 months from the initial date if no permits have been issued

A RECORDED SURVEY PLAT AND RECORDED DEED ARE REQUIRED WHEN APPLYING FOR A LAND USE APPLICATION

3/14 S

HTE 03-5-8425

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Doug Hytton (Weyerhaeuser)
Property Location: SR# 1266 Hicks Rd
New Installation, Septic Tank, Repairs, Nitrification Line

Subdivision Hicks Rd Tract Lot # 1

Tax ID # Quadrant #

Number of Bedrooms Proposed: 3 (50x50) Lot Size: 31.59 ac

Basement with Plumbing: Garage:

Water Supply: Well, Public, Community

Distance From Well: 100 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional, Other (pumps ultra shallow)

Size of tank: Septic Tank: 1000 gallons Pump Tank: 1000 gallons

Subsurface Drainage Field: No. of ditches 8, exact length of each ditch 75 ft., width of ditches 3 ft., depth of ditches 12 in. (MAX)

French Drain Required: Linear feet


Date: 02-04-04

This permit is subject to revocation if site plans or intended use change.

Signed: Joe WARS Environmental Health Specialist

SR 1266

Must meet onsite... MAJ not require pump... Keep well 100' from any part of septic system... Must Be in 8 to 12" of approved cover



meet onsite