

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner: *K.P.*

Applicant:

Address:

Date Evaluated:

Proposed Facility: *House*

Design Flow (.1949): *360*

Property Size:

Location of Site:

Property Recorded:

Water Supply:  Public  Individual  Well

Spring  Other

Evaluation Method:  Auger Boring  Pit

Cut

Type of Wastewater:  Sewage  Industrial Process

Mixed

1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
		.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
	024	SL	FR/GR	10YR 8/6	48			
	2448	SCL	FR/GR	10YR 6/6				
	024	SL	FR/GR	10YR 8/6	48			
	2448	SCL	FR/GR	10YR 6/6				
	024	SL	FR/GR	10YR 8/6	48			
	2448	SCL	FR/GR	10YR 6/6				
	024	SL	FR/GR	10YR 8/6	48			
	2448	SCL	FR/GR	10YR 6/6				
	024	SL	FR/GR	10YR 8/6	48			
	2448	SCL	FR/GR	10YR 6/6				
	024	SL	FR/GR	10YR 8/6	48			
	2448	SCL	FR/GR	10YR 6/6				

Description	Initial System	Repair System
Available Space (.1945)		
System Type(s)	GRAVEL	LEP
Site LTAR	.6	.3

Other Factors (.1946): \_\_\_\_\_  
 Site Classification (.1948): \_\_\_\_\_  
 Evaluated By: *[Signature]*  
 Others Present: *[Signature]*

*Change to 25% Red. SYSTEM TO save space*


COMMENTS: \_\_\_\_\_

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE	NS-NON-STICKY
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE					
FS-FOOT SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FR-FRIABLE	SS-SLIGHTLY STICKY
N-NOSE SLOPE		L-LOAM			
H-HEAD SLOPE	III	SI-SILT-	0.6 - 0.3	FI-FIRM	VS-VERY STICKY
CC-CONCLAVE SLOPE		SIL-SILT LOAM			
CV-CONVEX SLOPE		CL-CLAY LOAM			
T-TERRACE		SCL-SANDY CLAY LOAM			
FP-FLOOD PLAN		SICL-SILTY CLAY LOAM			
	IV	SIC-SILTY CLAY	0.4 - 0.1	EFI-EXTREMELY FIRM	NP-NON-PLASTIC
		C-CLAY			
		SC-SANDY CLAY			

STRUCTURE  
 SG-SINGLE GRAIN  
 M-MASSIVE  
 CR-CRUMB  
 GR-GRANULAR  
 SBK-SUBANGULAR BLOCKY  
 ABK-ANGULAR BLOCKY  
 PL-PLATY  
 PR-PRISMATIC

MINERALOGY  
 SLIGHTLY EXPANSIVE  
 EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).



SITE PLAN APPROVAL

DISTRICT AFABOR USE SFD

#BEDROOMS 3


6-30-04

ZONING ADMINISTRATOR

CAMDEN COURT EAST  
Wm. Kaut Pierce, Inc

Lot # 128 Highland Forest

(The Austin - Plan)



1" = 30'