HTE 04-5-9856

H NETT COUNTY HEALTH DEPAI ENT
ENVIRONMENTAL HEALTH SEC N

17428

OPERATIONS PERMIT

Name: (owner) Kent Pierce

☒ New Installation ☒ Septic Tank

Property Location: SR# 141

☐ Repairs ☒ Nitrification Line

Subdivision Highland Forest

Lot # 129

Tax ID #

Quadrant #

Contractor: Ted Brown

Registration #

Basement with Plumbing: ☐

Garage: ☒

Water Supply: ☐ Well ☒ Public ☐ Community

Distance From Well: 50 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: ☐ Conventional ☒ Other 25% Reduction System Infiltrator Quick 4 Chamber

Size of tank: Septic Tank: 500 gallons Pump Tank: gallons

Subsurface Drainage Field No. of ditches 1 exact length of each ditch 150 ft. width of ditches 3 ft. depth of ditches 18-24 in.

French Drain Required: Linear feet

Date: 12-13-04

Inspected by: [illegible]
Environmental Health Specialist

PERMIT NO. 20868