

HTE 04-5-9946 II

IMPROVEMENT PERMIT

21351

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Wellons Realty
Property Location: SR# 1435 Trapp RD
New Installation, Septic Tank, Repairs, Nitrification Line

Subdivision Plantation @ Vanguard Green Lot # 80

Tax ID # Quadrant #

Number of Bedrooms Proposed: 3 Lot Size: .486

Basement with Plumbing: Garage:
Water Supply: Well, Public, Community
Distance From Well: ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional, Other Pump to Manatee

Size of tank: Septic Tank: 1000 gallons Pump Tank: 1000 gallons


Subsurface Drainage Field: No. of ditches, exact length of each ditch, width of ditches, depth of ditches

French Drain Required: Linear feet
Date: 10-5-04

This permit is subject to revocation if site plans or intended use change.
Signed: James C. Monahan Environmental Health Specialist

\* ORIGINAL Permit # 20961 IS VOID BECAUSE OF DREG CHANGE.

- \* PUMP 40gpm @ 14.5'
\* MANATEE
- 3 3/4" SCH 40 VALVES
- 2' PRESSURE HEAD
- 2" SCH 40 PIPE



Pool Site

HARNETT COUNTY DEPARTMENT OF PUBLIC HEALTH  
AUTORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Department of Public Health, Improvement Permit # 21351. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. *This authorization will be invalid if ownership, site plans, or intended use change.*

Name Wellons Realty Telephone # 910-892-3123

Address P.O. Box 730 DUNN N.C. 28335

Property Location SR# 1435 Road Name Trepp

Subdivision Plantation at Vineyard Lot # 80 # Bedrooms Proposed 3 Lot Size .486

**TYPE OF SYSTEM**

- New Installation     Repair     Septic Tank     Nitrification Lines
- Conventional     Other Pump to Manholes
- Basement     With Plumbing     Without Plumbing

Water Supply:  Well     Public Water Supply Minimum Well Setback: \_\_\_\_\_ Ft.

Septic Tank 1000 gal    Pump Chamber 1000 gal

**NITRIFICATION FIELD SPECIFICATIONS**

Number of fields 2 # of lines per field 3 Length of lines 100 Ft.

Width of ditches 3 ft. Depth of ditches 24-28 inches

French Drain: Linear feet required \_\_\_\_\_ Depth of gravel \_\_\_\_\_

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.

Signature of Authorized Agent for Harnett County James E. Manhart Date 10-5-04