

HTE 04-5-10017

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Michael L Freeman☒ New Installation☒ Septic TankProperty Location: SR# 1538 Mabry Road☐ Repairs☒ Nitrification Line

Subdivision _____ Lot # _____

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 3 Lot Size: 22.11 acreBasement with Plumbing: ☐Garage: ☒Water Supply: ☐ Well☒ Public☐ CommunityDistance From Well: 50' ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: ☐ Conventional ☒ Other 25% Reduction SystemSize of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of Ditches 4 exact length of each ditch 80 ft. width of ditches 3 ft. depth of ditches 18-16 in. ^{map}

French Drain Required: - Linear feetDate: 8-20-04

This permit is subject to revocation if site plans or intended use change.

Signed: James E. Manhart
Environmental Health Specialist

