Department of Environment, Health, and Natural Resources Division of Environmental Health On-site Wastewater Section

Sheet: Property ID: Lot #: File #:

Code:

Applicant: Same

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner: Wellons Realty, Inc. Address: P.O. Box 730 Dunn NC 28335

Proposed Facility: house

Design Flow (.1949): 360 gallday

Location of Site: Slash Circle Water Supply:

[4] Public

[] Individual

[] Well

[]Pit

[] Spring [] Cut

[] Other

Evaluation Method: Type of Wastewater:

Sewage

Mauger Boring

[] Industrial Process

[] Mixed

Property Recorded:

Date Evaluated: 10/7/04 Property Size: . 74acres

P R O F			SOIL MORPHOLOGY		OTHER PROFILE FACTORS			1.47	
L E #	Landscape Position/ Slope%	Horizon Depth (IN.)	.1941 Structure/ Texture	,1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	Profile Class & LTAR
1	02%	0-43	'2	vfr, ns,np	standing water 7.5 YR 2.5/2@8"				S 1.0 US
S	U	0-48	Sgr	ufr, ns, np		48"			S 1.0
3		0.48	68 5	NEE NAME		48"			5 1,0
							The I		
	-								
		7.600					4.4		
							36		
				3				198	
						Maria de la compansión de	-		

Description	Initial System	Repair System
Available Space (.1945)		
System Type(s)	cen.	cen.
Site LTAR	1.0	1.0

PUMP TO 2260 @ 18-30"

Other Factors (.1946):

Site Classification (.1948): S

Evaluated By: JT / OT

Others Present: OT

FILE	#	
LILL	TT .	

LANDSCAPE POSITIONS

R-RIDGE S-SHOULDER SLOPE L-LINEAR SLOPE FS-FOOT SLOPE N-NOSE SLOPE H-HEAD SLOPE CC-CONCLAVE SLOPE CV-CONVEX SLOPE T-TERRACE FP-FLOOD PLAN

COMMENTS:

GROUP	TEXTURES	.1955 LTAR	CONSISTENCE MOIST	WET	
I	S-SAND LS-LOAMY SAND	1.2 - 0.8	VFR-VERY FRIABLE	NS-NON-STICKY	
п	SL-SANDY LOAM L-LOAM	0.8 – 0.6	FR-FRIABLE FI-FIRM VFI-VERY FIRM	SS-SLIGHTLY STICKY S-STICKY VS-VERY STICKY NP-NON-PLASTIC SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC	
Ш	SI-SILT- SIL-SILT LOAM CL-CLAY LOAM SCL-SANDY CLAY LOAM SICL-SILTY CLAY LOAM	0.6 – 0.3	EFI-EXTREMELY FIRM		

0.4 - 0.1

STRUCTURE SG-SINGLE GRAIN M-MASSIVE CR-CRUMB GR-GRANULAR SBK-SUBANGULAR BLOCKY ABK-ANGULAR BLOCKY PL-PLATY PR-PRISMATIC

MINERALOGY SLIGHTLY EXPANSIVE

SIC-SILTY CLAY


EXPANSIVE

C-CLAY SC-SANDY CLAY

IV

Show profile locations and other site features (dimensions, reference or benchmark, and North).

.(#####)



BEING ALL OF LOT 3, THE PINES, SECTION THREE, PLAT CABINET F, SLIDE 550C, HARNETT COUNTY REGISTRY

PLOTPLAN PREPARED FOR

Wellons Realty, Inc.

STEWARTS CREEK TOWNSHIP HARNETT CO. NORTH CAROLINA

SCALE: 1" = 50' JULY 27TH, 2004

> I, Ronnie E. Jordon, Professional Land Surveyor No. 2556, certify that this plot is a survey of an existing parcel or parcels of land.

NOTE: AREA BY COORDINATE COMPUTATION

I, Ronnie E. Jordan certify that this plat was drawn under my supervision from an actual survey made under my supervision (Deed description recorded in BookPC_F, Page411B.etc.)(other): that the boundaries not surveyed are clearly indicated as drawn from information found in Book

North Carolina, Sampson County
I, A Notary Public of the county and state aforesaid, certify that
Ronnie E. Jordan, a Professional Land Surveyor, personally appeared
before me this day and acknowledged the execution of the foregoing