

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner:

Applicant:

Address:

Date Evaluated:

Proposed Facility:

Design Flow (.1949):

Property Size:

Location of Site:

Property Recorded:

- Water Supply: Public Individual Well Spring Other
- Evaluation Method: Auger Boring Pit Cut
- Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
		024	LJ	FR/GA					
		2448	SCU	FR/GA		48			
		024	LS	FR/LR					
		2448	SCU	FR/GA		48			
		024	LS	FR/GA					
		2448	SCU	FR/GA		48			
		024	SL	FR/GA					
		2448	SCU	FR/GA		48			
		024	S2	FR/GA					
		2448	SCU	FR/GA		48			
		024	S2	FR/GA					
		2448	SCU	FR/LR		48			
		024	SL	FR/LR					
		2448	SCU	FR/LR		48			

Description	Initial System	Repair System
Available Space (.1945)		
System Type(s)	GRAVEL	LPP
Site LTAR	. 6	. 3

Other Factors (.1946): _____
 Site Classification (.1948): *gwa*
 Evaluated By: _____
 Others Present: *Holes by Steve*


COMMENTS: _____

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE	NS-NON-STICKY
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE					
FS-FOOT SLOPE					
N-NOSE SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FI-FIRM	S-STICKY
H-HEAD SLOPE		L-LOAM			
CC-CONCLAVE SLOPE	III	SI-SILT-	0.6 - 0.3	EFI-EXTREMELY FIRM	NP-NON-PLASTIC
CV-CONVEX SLOPE		SIL-SILT LOAM			
T-TERRACE		CL-CLAY LOAM			
FP-FLOOD PLAN		SCL-SANDY CLAY LOAM			
		SICL-SILTY CLAY LOAM			
	IV	SIC-SILTY CLAY	0.4 - 0.1		VP-VERY PLASTIC
		C-CLAY			
		SC-SANDY CLAY			

STRUCTURE
 SG-SINGLE GRAIN
 M-MASSIVE
 CR-CRUMB
 GR-GRANULAR
 SBK-SUBANGULAR BLOCKY
 ABK-ANGULAR BLOCKY
 PL-PLATY
 PR-PRISMATIC

MINERALOGY
 SLIGHTLY EXPANSIVE
 EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).




SITE PLAN APPROVAL

DISTRICT RA20R USE SFD

#BEDROOMS 3

B-13-04 D. Johnson
ZONING ADMINISTRATOR

< - N 87° 45' 36" W (90.000') -



< - N 87° 45' 36" W (90.000') -

MILLENNIUM HOMES
THE STEVENS
LOT#50 HIGHLAND FOREST
SCALE: 1"=40'

Permit Copy