

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner:

Applicant:

Address:

Date Evaluated:

Proposed Facility:

Design Flow (.1949):

Property Size:

Location of Site:

Property Recorded:

Water Supply:

Public [] Individual [] Well

[] Spring [] Other

Evaluation Method:

Auger Boring [] Pit

[] Cut

Type of Wastewater:

Sewage [] Industrial Process

[] Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
		024	SL	FR/LR		48			
		244	SCL	FR/LR					
		024	SL	FR/LR		48			
		244	SCL	FR/LR					
		024	SL	FR/LR		48			
		244	SCL	FR/LR					
		024	SL	FR/LR		48			
		244	SCL	FR/LR					
		024	SL	FR/LR		48			
		244	SCL	FR/LR					
		024	SL	FR/LR		48			
		244	SCL	FR/LR					

Description	Initial System	Repair System
Available Space (.1945)		
System Type(s)	Gravel	200
Site LTAR	1, 6	1, 3

Change to 20% Reduction 8/25/20

Other Factors (.1946): _____

Site Classification (.1948):

Evaluated By:

Others Present:

gut
Holes by Steve


COMMENTS: _____

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE	NS-NON-STICKY
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE					
FS-FOOT SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FR-FRIABLE	SS-SLIGHTLY STICKY
N-NOSE SLOPE		L-LOAM			
H-HEAD SLOPE	III	SI-SILT-	0.6 - 0.3	VFI-VERY FIRM	VS-VERY STICKY
CC-CONCLAVE SLOPE		SIL-SILT LOAM			
CV-CONVEX SLOPE		CL-CLAY LOAM			
T-TERRACE		SCL-SANDY CLAY LOAM			
FP-FLOOD PLAN		SICL-SILTY CLAY LOAM			
	IV	SIC-SILTY CLAY	0.4 - 0.1	EFI-EXTREMELY FIRM	NP-NON-PLASTIC
		C-CLAY			
		SC-SANDY CLAY			


STRUCTURE
 SG-SINGLE GRAIN
 M-MASSIVE
 CR-CRUMB
 GR-GRANULAR
 SBK-SUBANGULAR BLOCKY
 ABK-ANGULAR BLOCKY
 PL-PLATY
 PR-PRISMATIC

MINERALOGY
 SLIGHTLY EXPANSIVE
 EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).



Mastered
 Ring may
 not be
 needed



SITE PLAN APPROVAL
 DISTRICT RAZOR USE SFD
 #BEDROOMS 3
8/16/04 Phussell
 Date Zoning Administrator

$$AL = 42' - 9 \frac{1}{4}''$$

$$R = 50' - 0''$$

$$\Delta = 49.0103$$

NEW CENTURY HOMES
 THE FRANKLIN
 LOT# 72 HIGHLAND FOREST
 SCALE: 1"=40'

Permit Copy