

HTE 04-5-10183

IMPROVEMENT PERMIT

21233

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) JOHN COOPER New Installation Septic Tank
Property Location: SR# 1203 CALVARY CHURCH RD Repairs Nitrification Line

Subdivision CYPRESS CREEK FARMS Lot # 56

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 3 Lot Size: .91ac

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 100 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other PUMP TO 25% REDUCTION SYSTEM

Size of tank: Septic Tank: 1000 gallons Pump Tank: 1000 gallons

Subsurface Drainage Field No. of ditches 5 exact length of each ditch 50 ft. width of ditches 3 ft. depth of ditches 18-24 in.

French Drain Required: _____ Linear feet


Date: 9/22/04

This permit is subject to revocation if site plans or intended use change.

Signed: [Signature] RS (OLIVER TOLKSOEFF)
Environmental Health Specialist

DRAWING NTS

- * MAINTAIN ALL SETBACKS
- * SUPPLY LINE UNDER EASEMENT MUST BE SLEEVED
- * TANKS MAY BE MOVED BEHIND HOUSE AFTER FOOTINGS ARE ESTABLISHED MEETING WITH EHS MEETING WITH EHS REQUIRED FOR FINAL APPROVAL



HARNETT COUNTY DEPARTMENT OF PUBLIC HEALTH
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Department of Public Health, Improvement Permit # 04-5-10183. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. *This authorization will be invalid if ownership, site plans, or intended use change.*

JOHN COOPER 499-0410
Name Telephone #

PO Box 428 OLIVA NC 28368
Address

1203 CALVARY CHURCH RD
Property Location SR# Road Name

CYPRESS CREEK 56 3 .91AC
Subdivision Lot # # Bedrooms Proposed Lot Size

TYPE OF SYSTEM

- New Installation [] Repair Septic Tank Nitrification Lines
[] Conventional Other PUMP TO 25% REDUCTION SYSTEM
[] Basement [] With Plumbing [] Without Plumbing

Water Supply: [] Well Public Water Supply Minimum Well Setback: 100 Ft.

Septic Tank 1000 gal Pump Chamber 1000 gal

NITRIFICATION FIELD SPECIFICATIONS

Number of fields 1 # of lines per field 5 Length of lines 50 Ft.

Width of ditches 3 ft. Depth of ditches 18-24 inches

French Drain: Linear feet required _____ Depth of gravel _____

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.

[Signature]
Signature of Authorized Agent for Harnett County

9/22/04
Date