

HTE 04-5-10379

OPERATIONS PERMIT

Name: (owner) TRAVIS WEBB HOMES LLC New Installation Septic Tank
 Property Location: SR# 1291 Old US 421 Repairs Nitrification Line
 Subdivision MAMIE BELL RIDGE Lot # 50
 Tax ID # _____ Quadrant # _____
 Contractor: MIKE RAY Registration # _____

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 100 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 3 exact length of each ditch 80 ft. width of ditches 3 ft. depth of ditches 24 in.

French Drain Required: _____ Linear feet

Date: 10/18/04

Inspected by: [Signature] Environmental Health Specialist

PERMIT NO. 21236

