

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: *Custom Care*
 Address: *V-13*
 Proposed Facility:
 Location of Site:
 Water Supply: Public Individual Well
 Evaluation Method: Auger Boring Pit
 Type of Wastewater: Sewage Industrial Process

Applicant:
 Date Evaluated:
 Property Size:
 Property Recorded: Spring Other
 Cut
 Mixed

Design Flow (.1949): *360*

P R O F I L E #	1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
		<i>048</i>	<i>GR SL</i>	<i>VFR SW</i>		<i>48</i>			
		<i>048</i>	<i>GR SL</i>	<i>VFR SE</i>		<i>48</i>			
		<i>048</i>	<i>GR SL</i>	<i>VFR SE</i>		<i>48</i>			
		<i>048</i>	<i>GR SL</i>	<i>VFR SE</i>		<i>48</i>			
		<i>048</i>	<i>GR SL</i>	<i>VFR SE</i>		<i>48</i>			
		<i>048</i>	<i>GR SL</i>	<i>VFR SB</i>		<i>48</i>			
		<i>048</i>	<i>GR SL</i>	<i>VFR SB</i>		<i>48</i>			
		<i>048</i>	<i>GR SL</i>	<i>VFR SR</i>		<i>48</i>			
		<i>048</i>	<i>GR SL</i>	<i>VFR SL</i>		<i>48</i>			
		<i>048</i>	<i>GR SL</i>	<i>VFR SL</i>		<i>48</i>			

Description	Initial System	Repair System
Available Space (.1945)		
System Type(s)	<i>Cand</i>	<i>LPV</i>
Site LTAR	<i>.6</i>	<i>.7</i>

Other Factors (.1946): _____
 Site Classification (.1948): _____
 Evaluated By: *[Signature]*
 Others Present:

12700 - 11-24 until be fixed here 18" then on

COMMENTS: _____

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	NS-NON-STICKY SS-SLIGHTLY STICKY S-STICKY VS-VERY STICKY NP-NON-PLASTIC SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6		
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE	III	SI-SILT-	0.6 - 0.3		
H-HEAD SLOPE		SIL-SILT LOAM			
CC-CONCLAVE SLOPE		CL-CLAY LOAM			
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			
T-TERRACE		SICL-SILTY CLAY LOAM			
FP-FLOOD PLAN	IV	SIC-SILTY CLAY	0.4 - 0.1		
		C-CLAY			
		SC-SANDY CLAY			

STRUCTURE

- SG-SINGLE GRAIN
- M-MASSIVE
- CR-CRUMB
- GR-GRANULAR
- SBK-SUBANGULAR BLOCKY
- ABK-ANGULAR BLOCKY
- PL-PLATY
- PR-PRISMATIC

MINERALOGY

- SLIGHTLY EXPANSIVE
- EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).



