

HTE # 04-5-10866

H WETT COUNTY HEALTH DEPAR TMENT  
ENVIRONMENTAL HEALTH SECTION

17681

# OPERATIONS PERMIT

Name: (owner) JACKIE + STAN ALTMAN  New Installation  Septic Tank  Repair

Property Location: SR# 1705 OLD FAEGROUND  Nitrification Line  Expansion

Subdivision Leigh Laurel Lot # 11 Tax ID # \_\_\_\_\_ Quadrant # \_\_\_\_\_

Contractor: Gerald Temple Registration # 9

Basement with Plumbing:  Garage:

Water Supply:  Well  Public  Community

Distance From Well: 50' ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system:  Conventional  Other \_\_\_\_\_

Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons

Subsurface Drainage Field No. of ditches 3 exact length of each ditch 115 ft. width of ditches 3 ft. depth of ditches 24-28 in.

French Drain Required: - Linear feet

Date: 6-24-05

PERMIT NO. 21384

Inspected by: James E. Marshall

