

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: *Paul Santini*

Applicant: *←*

Address: _____

Date Evaluated: *1/26/05*

Proposed Facility: *4BR Hk.*

Design Flow (.1949): *480*

Property Size: *3.78*

Location of Site: *Hoover Rd*

Property Recorded: _____

Water Supply: Public Individual Well Spring Other

Evaluation Method: Auger Boring Pit Cut

Type of Wastewater: Sewage Industrial Process Mixed

400 is 960 520ft line

Profile #	.1940 Landscape Position/Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941			OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/Texture	.1941 Consistence	.1941 Mineralogy	.1942 Soil Wetness/Color	.1943 Soil Depth (N.)	.1956 Sapro Class	.1944 Restr Horiz	
<i>SS 27.</i>		<i>0-18"</i>	<i>SL Gr</i>	<i>NSNP</i>	<i>Fi</i>					<i>0.5 PS</i>
		<i>18-36"</i>	<i>SCL S/BK</i>	<i>SSSP</i>	<i>Fi</i>					
		<i>36-48"</i>	<i>CL SBK</i>	<i>SP</i>	<i>Fi</i>	<i>104R 44</i>	<i>748"</i>			
<i>#2</i>		<i>0-32"</i>	<i>SL Gr</i>	<i>NSNP</i>	<i>Fi</i>					<i>0.6 PS</i>
		<i>32-48"</i>	<i>SCL SBK</i>	<i>SSSP</i>	<i>Fi</i>	<i>104R 7/4</i>	<i>748"</i>			
<i>#3</i>		<i>0-34"</i>	<i>SL Gr</i>	<i>NSNP</i>	<i>Fi</i>					<i>0.5 PS</i>
		<i>34-48"</i>	<i>SCL SBK</i>	<i>SSSP</i>	<i>Fi</i>	<i>104R 2/4</i>	<i>748"</i>			
<i>#4</i>		<i>0-32"</i>	<i>SL Gr</i>	<i>NSNP</i>	<i>Fi</i>					<i>0.5 PS</i>
		<i>32-48"</i>	<i>SCL SBK</i>	<i>SSSP</i>	<i>Fi</i>	<i>104R 6/4</i>				
<i>#5</i>		<i>0-18"</i>	<i>SL Gr</i>	<i>NSNP</i>	<i>Fi</i>					<i>0.5 PS</i>
		<i>18-32"</i>	<i>SCL SBK</i>	<i>SSSP</i>	<i>Fi</i>					
		<i>32-48"</i>	<i>CL SBK</i>	<i>SB</i>		<i>104R 6/4</i>				
<i>#6 Front Wall</i>		<i>0-30"</i>	<i>SL Gr</i>	<i>NSNP</i>	<i>Fi</i>					<i>0.5 PS</i>
		<i>30-46"</i>	<i>SCL Gr</i>	<i>SSSP</i>	<i>Fi</i>	<i>104R 7/4</i>				
<i>#7 1st x 4th</i>		<i>0-20"</i>	<i>SL Gr</i>	<i>NSNP</i>	<i>Fi</i>					<i>0.5 PS</i>
		<i>20-46"</i>	<i>SCL SBK</i>	<i>SSSP</i>	<i>Fi</i>	<i>104R 7/2 R 38"</i>				

Description	Initial System	Repair System
Available Space (.1945)	<i>CONV ✓</i>	<i>LPP ✓</i>
System Type(s)	<i>CONV</i>	<i>LPP</i>
Site LTAR	<i>0.5</i>	<i>0.25</i>

Other Factors (.1946): _____
 Site Classification (.1948): *PS*
 Evaluated By: *WAC*
 Others Present: _____

