

Sheet:
 Property ID:
 Lot #:
 File #:
 Code:

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner:
 Address:
 Proposed Facility:
 Location of Site:

Applicant:

Date Evaluated:

Property Size:

Property Recorded:

Water Supply: Public Individual Well
 Evaluation Method: Auger Boring Pit
 Type of Wastewater: Sewage Industrial Process

Spring Other
 Cut
 Mixed

Profile #	1940 Landscape Position/Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY 1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			1941 Structure/Texture	1941 Consistence Mineralogy	1942 Soil Wetness/Color	1943 Soil Depth (IN.)	1956 Sapro Class	1944 Restr Horiz	
		0-24	GR SL	VFA SF					
		24-42	SDH CL	FA SF		✓			
		0-18	GR SL	VFA SF					
		18-42	SDH CL	FA SF		✓			
		42-48	SDH CL	FZ SF					
		12-18	GR SL	VFA SF					
		18-42	SBK CL	FA SF		✓			
		42-48	SBK SC	FZ SF					
		0-24	GR SL	VFA SF					
		24-42	SDH CL	FA SF		✓			
		0-24	GR SL	VFA SF					
		24-42	SDH CL	FA SF		✓			
		0-24	GR SL	VFA SF					
		24-42	SDH CL	FA SF		✓			

Description	Initial System	Repair System
Available Space (.1945)		Gravelles
System Type(s)	GRAVEL	SDH
Site LTAR	.3	.3

1x300 25% M

Other Factors (.1946):
 Site Classification (.1948):
 Evaluated By: *JLH*
 Others Present: *M.E.*


COMMENTS: _____

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	NS-NON-STICKY SS-SLIGHTLY STICKY S-STICKY VS-VERY STICKY NP-NON-PLASTIC SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6		
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE	III	SI-SILT-	0.6 - 0.3		
H-HEAD SLOPE		SIL-SILT LOAM			
CC-CONCLAVE SLOPE		CL-CLAY LOAM			
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			
T-TERRACE	IV	SIC-SILTY CLAY	0.4 - 0.1		
FP-FLOOD PLAN		C-CLAY			
		SC-SANDY CLAY			

STRUCTURE
 SG-SINGLE GRAIN
 M-MASSIVE
 CR-CRUMB
 GR-GRANULAR
 SBK-SUBANGULAR BLOCKY
 ABK-ANGULAR BLOCKY
 PL-PLATY
 PR-PRISMATIC

MINERALOGY
 SLIGHTLY EXPANSIVE
 EXPANSIVE


Show profile locations and other site features (dimensions, reference or benchmark, and North).



1=20'

"NUT TREE CIRCLE" 50' R/W

"COTTONADE CIRCLE" 50' R/W



3x80
35% rd.

SITE PLAN APPROVAL

DISTRICT BOARD USE SFD

#BEDROOMS 3

Date October 1, 2000

Zoning Administrator [Signature]

53

Handwritten notes and scribbles at the bottom right.