HTE # 04-50011062

ARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION

17829

OPERATIONS PERMIT

Name: (owner) Cavines Land ☒ New Installation ☒ Septic Tank ☐ Repair

Property Location: SR# 1117 ☒ Nitrification Line ☐ Expansion

Subdivision Woodshire Lot # 92 Tax ID # _____ Quadrant # _____

Contractor: D.C. Carter Registration # _____

Basement with Plumbing: ☐ Garage: ☒

Water Supply: ☐ Well ☒ Public ☐ Community

Distance From Well: 50 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: ☐ Conventional ☒ Other 25% Reduction system E-2-Flow

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field	No. of ditches 1	exact length of each ditch 180 ft.	width of ditches 3 ft.	depth of ditches 18-24 in.

French Drain Required: _____ Linear feet Date: 7-15-05

PERMIT NO. 21518 Inspected by: [illegible]