

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:

Applicant:

Address:

Date Evaluated:

Proposed Facility:

Design Flow (.1949):

Property Size:

Location of Site:

Property Recorded:

Water Supply:

- Public     Individual     Well     Spring     Other

Evaluation Method:

- Auger Boring     Pit     Cut

Type of Wastewater:

- Sewage     Industrial Process     Mixed

P R O F I L E #	1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	1942 Soil Wetness/ Color	1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
		0-20	GR SL	VFR SF					
		20-30	SBK SC	FR SF					
		30-42	SDK SC	F2 SF					
		42-48	PM	Pract msh		42			J
		0-30	GR SC	VFR SF					
		30-36	SDK SC	F2 SF					
		36+	CR2	exp clay	36" CR2	36			.3
		0-36	GR SL	VFR SF					
		36-48	SBK SC	F2 SF	CR2 @ 42	42			.6
		0-30	GR SL	VFR SF					
		30-36	SBK SC	F2 SF					
		36+	CR2		36'	36			.3
		0-30	GR SL	VFR SF					
		30-36	SDK SC	F2 SF					
		36+	CR2		36 CR2	J			.3

Description	Initial System	Repair System
Available Space (.1945)		
System Type(s)	GRAVEL	LPS
Site LTAR	.J	.15

Other Factors (.1946): \_\_\_\_\_  
 Site Classification (.1948): \_\_\_\_\_  
 Evaluated By: *J. W.*  
 Others Present: *A. J. ...*


COMMENTS: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	NS-NON-STICKY SS-SLIGHTLY STICKY S-STICKY VS-VERY STICKY NP-NON-PLASTIC SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6		
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE	III	SI-SILT-	0.6 - 0.3		
H-HEAD SLOPE		SIL-SILT LOAM			
CC-CONCLAVE SLOPE		CL-CLAY LOAM			
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			
T-TERRACE		SICL-SILTY CLAY LOAM			
FP-FLOOD PLAN	IV	SIC-SILTY CLAY	0.4 - 0.1		
		C-CLAY			
		SC-SANDY CLAY			

STRUCTURE  
 SG-SINGLE GRAIN  
 M-MASSIVE  
 CR-CRUMB  
 GR-GRANULAR  
 SBK-SUBANGULAR BLOCKY  
 ABK-ANGULAR BLOCKY  
 PL-PLATY  
 PR-PRISMATIC


MINERALOGY  
 SLIGHTLY EXPANSIVE  
 EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).



(#####)





SITE PLAN APPROVAL  
 DISTRICT KAZOR USE SFD  
 #BEDROOMS 3  
 Date 1/4/05 Zoning Administrator PJR

$1=20'$   
 74  
 1/2300 18" 25% Reduc  
 73