epartment of Environment, Health, and Natural Resources
ivision of Environmental Health
n-site Wastewater Section

Sheet:
Property ID:
Lot #:
File #:
Code:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner:
Address:
roposed Facility:
ocation of Site:
Applicant:
Date Evaluated:
Property Size:
Property Recorded:

Design Flow (.1949):

Vater Supply: [X] Public [ ] Individual [ ] Well [ ] Spring [ ] Other
valuation Method: [X] Auger Boring [ ] Pit [ ] Cut
ype of Wastewater: [X] Sewage [ ] Industrial Process [ ] Mixed

PROFILE #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941 .1941 Structure/ Texture	.1941 Consistence Mineralogy	OTHER PROFILE FACTORS .1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	Profile Class & LTAR
		0-18	GR SL	VFR SE		18			
		18-28	SBK SCL	FR SE					
		28-38	SBK SC	FR SE					
		0-4	GR SL	VFR SE		4			
		0-4	GR SL	VFR SE		4+6			
		0-4	GR SL	VFR SE		4			
		0-4	GR SL	VFR SE		4+6			
		0-4	GR SL	VFR SE		4			
		0-18	GR SL	VFR SF					
		18-28	SBK SCL	FR SE		4+			
		28-40	SBK SL	FR SE					

Description	Initial System	Repair System
Available Space (.1945)		
System Type(s)	Gravel	LPP
Site LTAR	.64	.2

Other Factors (.1946):
Site Classification (.1948):
Evaluated By:
Others Present:

FILE #_____

COMMENTS:_____

LANDSCAPE POSITIONS	GROUP	TEXTURES	.1955 LTAR	CONSISTENCE MOIST	WET
R-RIDGE	I	S-SAND	1.2 - 0.8		
S-SHOULDER SLOPE		LS-LOAMY SAND		VFR-VERY FRIABLE	NS-NON-STICKY
L-LINEAR SLOPE				FR-FRIABLE	SS-SLIGHTLY STICKY
FS-FOOT SLOPE	II	SL-SANDY LOAM	0.8 – 0.6	FI-FIRM	S-STICKY
N-NOSE SLOPE		L-LOAM		VFI-VERY FIRM	VS-VERY STICKY
H-HEAD SLOPE				EFI-EXTREMELY FIRM	NP-NON-PLASTIC
CC-CONCLAVE SLOPE	III	SI-SILT-	0.6 – 0.3		SP-SLIGHTLY STICKY
CV-CONVEX SLOPE		SIL-SILT LOAM			P-PLASTIC
T-TERRACE		CL-CLAY LOAM			VP-VERY PLASTIC
FP-FLOOD PLAN		SCL-SANDY CLAY LOAM			
		SICL-SILTY CLAY LOAM			
	IV	SIC-SILTY CLAY	0.4 – 0.1		
		C-CLAY			
		SC-SANDY CLAY			

STRUCTURE
SG-SINGLE GRAIN
M-MASSIVE
CR-CRUMB
GR-GRANULAR
SBK-SUBANGULAR BLOCKY
ABK-ANGULAR BLOCKY
PL-PLATY
PR-PRISMATIC

MINERALOGY
SLIGHTLY EXPANSIVE

EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).



.(######)

SITE PLAN APPROVAL

DISTRICT RA2&R USE SFD

#BEDROOMS 3

1/18/05 PJR

Date Zoning Administrator



S&K HOMES LLC. INC.

THE JORDAN

LOT #182 CRESTVIEW

SCALE: 1"=40'

Permit Copy