

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner:

Applicant:

Address:

Date Evaluated:

Proposed Facility:

Design Flow (.1949):

Property Size:

Location of Site:

Property Recorded:

Water Supply:

Public [] Individual

[] Well

[] Spring

[] Other

Evaluation Method:

Auger Boring

[] Pit

[] Cut

Type of Wastewater:

Sewage

[] Industrial Process

[] Mixed

Profile #	.1940 Landscape Position/Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
		0-18	GR SL	VFR	SE				
		18-30	SBK SCL	FR	SE				
		30-48	SBK SC	FZ	SE				
		0-12	GR SL	VFR	SE				
		12-18	SBK SCL	FR	SE				
		18-36	SBK SC	FZ	SE				
		36				CR 2			
		0-24	GR SL	VFR	SE				
		24-36	SBK SCL	FR	SE				
		36-48	SBK SC	FZ	SE				
		0-24	GR SL	VFR	SE				
		24-36	SBK SCL	FR	SE				
		36-48	SBK SC	FZ	SE				
		0-24	GR SL	VFR	SE				
		24-36	SBK SCL	FR	SE				
		36-48	SBK SC	FZ	SE				
		0-24	GR SL	VFR	SE				
		24-36	SBK SCL	FR	SE				
		36-48	SBK SC	FZ	SE				

SEL

Description	Initial System	Repair System
Available Space (.1945)		
System Type(s)	GRAVEL	LOP
Site LTAR	.3	.15

Other Factors (.1946): _____

Site Classification (.1948): _____

Evaluated By: *[Signature]*

Others Present: *[Signature]*

Chng z 21% M 1X300
1811


COMMENTS: _____

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE	NS-NON-STICKY
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FR-FRIABLE	SS-SLIGHTLY STICKY
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE	III	SI-SILT-	0.6 - 0.3	FI-FIRM	S-STICKY
H-HEAD SLOPE		SIL-SILT LOAM			
CC-CONCLAVE SLOPE		CL-CLAY LOAM			
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			
T-TERRACE	IV	SIC-SILTY CLAY	0.4 - 0.1	EFI-EXTREMELY FIRM	NP-NON-PLASTIC
FP-FLOOD PLAN		C-CLAY			
		SC-SANDY CLAY			SP-SLIGHTLY STICKY
					P-PLASTIC
					VP-VERY PLASTIC

STRUCTURE
 SG-SINGLE GRAIN
 M-MASSIVE
 CR-CRUMB
 GR-GRANULAR
 SBK-SUBANGULAR BLOCKY
 ABK-ANGULAR BLOCKY
 PL-PLATY
 PR-PRISMATIC

MINERALOGY
 SLIGHTLY EXPANSIVE
 EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).




SITE PLAN APPROVAL

DISTRICT R200R USE SFD

#BEDROOMS 3

11/01/05 A. Duggan 31°05'15" N 130°08'00" W
Date Zoning Administrator



S&K HOMES LLC. INC.
THE MANCHESTER
LOT #225 CRESTVIEW
SCALE: 1"=40'

Permit Copy