



HARNETT COUNTY DEPARTMENT OF PUBLIC HEALTH  
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Department of Public Health, Improvement Permit # 21965. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. *This authorization will be invalid if ownership, site plans, or intended use change.*

Name Jeff W. Huber Holly Ridge Homes Telephone # 919 484-4297  
~~890 3941~~

Address P.O. Box 2105 Lillington, N.C. 27546

Property Location SR# 1437 Road Name Ballard

Subdivision Ballard Woods Lot # 28 # Bedrooms Proposed 3 Lot Size \_\_\_\_\_

**TYPE OF SYSTEM**

- New Installation    Repair    Septic Tank    Nitrification Lines  
 Conventional    Other 25% Reduct. System  
 Basement    With Plumbing    Without Plumbing

Water Supply:  Well    Public Water Supply Minimum Well Setback: 50 Ft.

Septic Tank 1000 gal   Pump Chamber \_\_\_\_\_ gal

**NITRIFICATION FIELD SPECIFICATIONS**

Number of fields 1 # of lines per field 5 Length of lines 60 Ft.  
Width of ditches 3 ft. Depth of ditches 12 inches <sup>MAX</sup>  
6 inches if cover  
French Drain: Linear feet required \_\_\_\_\_ Depth of gravel \_\_\_\_\_

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.

[Signature]  
Signature of Authorized Agent for Harnett County

4/27/2005  
Date