

Property ID:  
 Lot #:  
 File #:  
 Code:

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

WEATHER  
 RAIN + 36°

Owner:  
 Address:  
 Proposed Facility: 3 BDRM HOUSE Design Flow (.1949): 360 gpd  
 Location of Site:  
 Water Supply:  Public  Individual  Well  
 Evaluation Method:  Auger Boring  Pit  
 Type of Wastewater:  Sewage  Industrial Process

Applicant:  
 Date Evaluated: 2/24/05  
 Property Size:  
 Property Recorded:  Spring  Other  
 Pit  Cut  
 Mixed

1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR	
		.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz		
L 5-7%	0-6"	SBK SCL	FR ss/sc					PS .3	
	6-32"	SBK C	FR s/p						
	32"	~50% PM							
	0-14"	SBK SCL	FR s <sub>2</sub> /s <sub>2</sub> p					PS .3	
	14-24"	SBK CL	FR s/p						
	24-32"	SBK SCL <sup>W</sup> PM	FR s/s <sub>2</sub> p						
		ROCK @ 32"							

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	PUMP TO INNOV.	LPP
Site LTAR	.3	.15

Other Factors (.1946): \_\_\_\_\_  
 Site Classification (.1948): PS  
 Evaluated By: [Signature]  
 Others Present: BM

1 x 300 @ 18" ON DOWNHILL SIDE  
 LPP REPAIR  
 EXACT LAYOUT TO BE DETERMINED WHEN SITE IS CLEARED