

HTE 05-5-11313

IMPROVEMENT PERMIT

21632

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Rob + Pamela DIZANE New Installation Septic Tank
Property Location: SR# N.C. 42 Repairs Nitrification Line

Subdivision _____ Lot # _____

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 4 Lot Size: 3.4 ac

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 100' ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other 25% Reduction system

Size of tank: Septic Tank: 1200 gallons Pump Tank: _____ gallons


Subsurface Drainage Field No. of ditches 5 exact length of each ditch 80 ft. width of ditches 3 ft. depth of ditches 20 \rightarrow 18 in.

French Drain Required: _____ Linear feet

Date: 2-25-05

This permit is subject to revocation if site plans or intended use change.

Signed: James E. Manshart ⁰²³
Environmental Health Specialist



05-5-11313

HARNETT COUNTY HEALTH DEPARTMENT AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department, Improvement Permit # 21632. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. *This authorization will be invalid if ownership, site plans, or intended use change.*

Name Rob + Pamela Drake Telephone# 919-567-2399

Address 9307 N.C. 42 Holly Springs N.C. 27540

Property Location SR# N.C. 42 Road Name N.C. 42

Subdivision _____ Lot # 4 # Bedrooms Proposed _____ Lot Size 3.4

TYPE OF SYSTEM

New Installation Repair Septic Tank Nitrification Lines

Conventional Other 25% Reduction System

Basement With Plumbing Without Plumbing

Water Supply: Well Public Water Supply Minimum Well Setback: 100 Ft.

Septic Tank 1200 gal Pump Chamber _____ gal

NITRIFICATION FIELD SPECIFICATIONS

Number of fields 2 # of lines per field 5 Length of lines 80 Ft.

Width of ditches 3 ft. Depth of ditches 22-218 inches

French Drain: Linear feet required _____ Depth of gravel _____

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.

James E. Markham
Signature of Authorized Agent for Harnett County of Harnett

2-25-05
Date