

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:

Applicant:

Address:

Date Evaluated:

Proposed Facility:

Design Flow (.1949):

Property Size:

Location of Site:

Property Recorded:

- Water Supply:  Public     Individual     Well     Spring     Other
- Evaluation Method:  Auger Boring     Pit     Cut
- Type of Wastewater:  Sewage     Industrial Process     Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
		0-36	GR SL	VLR SP					.5
		36-48	SBK SL	FR SO					
		0-36	GR SL	VLR SP					.5
		2-48	SBK SL	FR SO					
		0-30	GR SL	VLR SP					.5
		30-48	SBK SL	FR SO					
		0-30	GR SL	VLR SP					.5
		30-48	SBK SL	FR SB					
		0-36	GR SL	VLR SP					.5
		36-48	SBK SL	FR SB					
		0-36	GR SL	VLR SP					.5
		36-48	SBK SL	FR SB					
		0-36	GR SL	VLR SP					.5
		36-48	SBK SL	FR SB					

Description	Initial System	Repair System
Available Space (.1945)		
System Type(s)	Gravel	VLR
Site LTAR	.5	.25

Other Factors (.1946): \_\_\_\_\_  
 Site Classification (.1948): \_\_\_\_\_  
 Evaluated By: *[Signature]*  
 Others Present: \_\_\_\_\_

*Change to 25% R/L to 100%  
 100%*




COMMENTS: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_


<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	NS-NON-STICKY SS-SLIGHTLY STICKY S-STICKY VS-VERY STICKY NP-NON-PLASTIC SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6		
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE	III	SI-SILT-	0.6 - 0.3		
H-HEAD SLOPE		SIL-SILT LOAM			
CC-CONCLAVE SLOPE		CL-CLAY LOAM			
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			
T-TERRACE		SICL-SILTY CLAY LOAM			
FP-FLOOD PLAN	IV	SIC-SILTY CLAY	0.4 - 0.1		
		C-CLAY			
		SC-SANDY CLAY			

STRUCTURE  
 SG-SINGLE GRAIN  
 M-MASSIVE  
 CR-CRUMB  
 GR-GRANULAR  
 SBK-SUBANGULAR BLOCKY  
 ABK-ANGULAR BLOCKY  
 PL-PLATY  
 PR-PRISMATIC

MINERALOGY  
 SLIGHTLY EXPANSIVE  
 EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).





27 95  
of 25% rule  
11.24

72

Note  
Power / Phone  
cable / water  
to come up  
Along proposed  
lines with  
the 10  
Area 14982  
SYSTEM  
CANN

#5 WH  
An  
#2  
↑ 15 Top 10

SITE PLAN APPROVAL  
DISTRICT RAZOR USE SFU  
#BEDROOMS 3  
2/8/05 DJR  
Date Zoning Administrator

"UNION CIRCLE" 50' R/W

1=20