

# HARNETT COUNTY DEPARTMENT OF PUBLIC HEALTH AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Department of Public Health, Improvement Permit # 22782. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. *This authorization will be invalid if ownership, site plans, or intended use change.*

Bradley Built INC Name 639-2023 Telephone #

466 STANCO RD Angier N.C. 27501 Address

1415 Property Location SR# Rands Ct RD Road Name

Alex Park Subdivision 4 Lot # 3 3606PD # Bedrooms Proposed 1.03 Lot Size

### TYPE OF SYSTEM

- New Installation    Repair    Septic Tank    Nitrification Lines
- Conventional    Other 25% Reduction Syst
- Basement    With Plumbing    Without Plumbing
- Water Supply:  Well    Public Water Supply Minimum Well Setback: \_\_\_\_\_ Ft.
- Septic Tank 1000 gal   Pump Chamber \_\_\_\_\_ gal

### NITRIFICATION FIELD SPECIFICATIONS

Number of fields 2 # of lines per field 1 Length of lines 300 Ft.  
 Width of ditches 3 ft. Depth of ditches 22 inches  
 French Drain: Linear feet required - Depth of gravel -

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.

James E. Markham  
Signature of Authorized Agent for Harnett County

12-12-05  
Date