

### SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner: \_\_\_\_\_ Applicant: \_\_\_\_\_  
 Address: \_\_\_\_\_ Date Evaluated: \_\_\_\_\_  
 Proposed Facility: \_\_\_\_\_ Design Flow (.1949): \_\_\_\_\_ Property Size: \_\_\_\_\_  
 Location of Site: \_\_\_\_\_ Property Recorded: \_\_\_\_\_  
 Water Supply:  Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process  Mixed

Profile #	1940 Landscape Position/Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY 1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			1941 Structure/Texture	1941 Consistence Mineralogy	1942 Soil Wetness/Color	1943 Soil Depth (IN.)	1956 Sapro Class	1944 Restr. Horiz	
1	L	0-2	SL	FR GN NSNP					-
		2-24	SCL	SLFM <sup>1W</sup> SBL S.P					
		24+	Snp	- Group II out					
2	L	0-10	SL	FR GN NSND					.35
		10-42	SCL	SLFM <sup>1W</sup> SBL S.P	34				
3	L	0-8	SL	FR GN NSND					.4
		8-42	SCL	SLFM <sup>1W</sup> SBL S.P	36				

Description	Initial System	Repair System
Available Space (.1945)		
System Type(s)	25" Red	6PP Paper
Site LTAR	.4	.3

Other Factors (.1946): \_\_\_\_\_  
 Site Classification (.1948): \_\_\_\_\_  
 Evaluated By: \_\_\_\_\_  
 Others Present: \_\_\_\_\_