HTE 05-SD011524R

RNETT COUNTY HEALTH DEPA MENT
ENVIRONMENTAL HEALTH SEC ION

17266

OPERATIONS PERMIT

Name: (owner) Kent Pierce

☒ New Installation ☒ Septic Tank

Property Location: SR# 1115

☐ Repairs ☒ Nitrification Line

Subdivision CRESTVIEW

Lot # 221

Tax ID #

Quadrant #

Contractor: Ted Brown

Registration #

Basement with Plumbing: ☐

Garage: ☒

Water Supply: ☐ Well ☒ Public ☐ Community

Distance From Well: 50 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: ☐ Conventional ☒ Other 25% Reduction SYSTEM Infiltrator Quick 4

Size of tank: Septic Tank: 1000 gallons Pump Tank: gallons

Subsurface Drainage Field: No. of ditches 1; exact length of each ditch 300 ft. of chamber; width of ditches 3 ft.; depth of ditches 18 in.

French Drain Required: Linear feet

Date: 6-30-05

Inspected by: [signature]
Environmental Health Specialist

PERMIT NO. 21944