

**SOIL/SITE EVALUATION**  
 for ON-SITE WASTEWATER SYSTEM

Owner: # 11550

Applicant:

Address:

Date Evaluated:

Proposed Facility:

Design Flow (.1949):

Property Size:

Location of Site:

Property Recorded:

Water Supply:

Public     Individual     Well

Spring     Other

Evaluation Method:

Auger Boring     Pit

Cut

Type of Wastewater:

Sewage     Industrial Process

Mixed

1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
		.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
	04Y	GR SL	VFA JG		42			.6
	04Y	GR SL	VFA SB		42			.6
	04Y	GR SL	VFA SB		46			.6
	04Y	GR SL	VFA SB		42			.6
	04Y	GR SL	VFA SA		48			.6
	04Y	GR SL	VFA SB		48			.6
	04Y	GR SL	VFA SB		.48			.6

Description	Initial System	Repair System
Available Space (.1945)		
System Type(s)	GA	W.P.
Site LTAR	.6	.3 (2% LF)

Other Factors (.1946): \_\_\_\_\_  
 Site Classification (.1948): \_\_\_\_\_  
 Evaluated By: J. W. [Signature]  
 Others Present: S. [Signature]

Chng 2 25% Ml SOR 4~

COMMENTS: \_\_\_\_\_

\_\_\_\_\_


\_\_\_\_\_

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE	NS-NON-STICKY
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FR-FRIABLE	SS-SLIGHTLY STICKY
FS-FOOT SLOPE		L-LOAM		FI-FIRM	S-STICKY
N-NOSE SLOPE				VFI-VERY FIRM	VS-VERY STICKY
H-HEAD SLOPE	III	SI-SILT-	0.6 - 0.3	EFI-EXTREMELY FIRM	NP-NON-PLASTIC
CC-CONCLAVE SLOPE		SIL-SILT LOAM			SP-SLIGHTLY STICKY
CV-CONVEX SLOPE		CL-CLAY LOAM			P-PLASTIC
T-TERRACE		SCL-SANDY CLAY LOAM			VP-VERY PLASTIC
FP-FLOOD PLAN		SICL-SILTY CLAY LOAM			
	IV	SIC-SILTY CLAY	0.4 - 0.1		
		C-CLAY			
		SC-SANDY CLAY			

STRUCTURE  
 SG-SINGLE GRAIN  
 M-MASSIVE  
 CR-CRUMB  
 GR-GRANULAR  
 SBK-SUBANGULAR BLOCKY  
 ABK-ANGULAR BLOCKY  
 PL-PLATY  
 PR-PRISMATIC


MINERALOGY  
 SLIGHTLY EXPANSIVE  
 EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).



Dennis

Highland  
Dr. W



SITE PLAN APPROVAL

DISTRICT RAA02 USE SFD

#BEDROOMS 3

D. Blalock  
Date  
Zoning Administrator

3/24/15  
2/15/15

Dennis

DENNIS NORRIS BUILDERS INC.  
 THE LAKELAND  
 LOT #9 HIGHLAND FOREST  
 SCALE: 1"=40'