

HTE 055001815

IMPROVEMENT PERMIT

21684

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) MICHAEL ANDERSON HOMES INC
Property Location: SR# 1443 LAFAYETTE RD
New Installation, Septic Tank, Repairs, Nitrification Line

Subdivision VICTORIA HILLS Lot # 55

Tax ID # Quadrant #

Number of Bedrooms Proposed: 3 Lot Size: 30529 sq ft

Basement with Plumbing: Garage:
Water Supply: Well, Public, Community
Distance From Well: 100 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional, Other

Size of tank: Septic Tank: 1000 gallons Pump Tank: gallons

Subsurface Drainage Field No. of ditches 3 exact length of each ditch 110 ft. width of ditches 3 ft. depth of ditches 30-24 in. START @ 30"


French Drain Required: Linear feet

Date: 4/19/05

Signed: [Signature] Environmental Health Specialist

This permit is subject to revocation if site plans or intended use change.

- * MAINTAIN ALL SETBACKS
* SET TANK SHALLOW TO AVOID A PUMP.
* START LINES AT 30" DEEP
* CALL WITH ANY QUESTIONS PRIOR TO INSTALLATION



HARNETT COUNTY DEPARTMENT OF PUBLIC HEALTH
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Department of Public Health, Improvement Permit # 21684. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. *This authorization will be invalid if ownership, site plans, or intended use change.*

Name MICHAEL ANDERSON HOMES INC Telephone # 919-552-1790

Address 180 WOODLAND RIDGE DR FUQUAY-VARINA NC 27526

Property Location SR# 1443 Road Name LAFAYETTE RD

Subdivision Victoria Hills Lot # 55 # Bedrooms Proposed 3 Lot Size 30529ft²

TYPE OF SYSTEM

- New Installation [] Repair Septic Tank Nitrification Lines
 Conventional [] Other _____
[] Basement [] With Plumbing [] Without Plumbing

Water Supply: [] Well Public Water Supply Minimum Well Setback: 100 Ft.

Septic Tank 1000 gal Pump Chamber _____ gal


NITRIFICATION FIELD SPECIFICATIONS

Number of fields 1 # of lines per field 3 Length of lines 110 Ft.

Width of ditches 3 ft. Depth of ditches 30-24 inches

French Drain: Linear feet required _____ Depth of gravel _____

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.

 Signature of Authorized Agent for Harnett County

4/11/05
Date