

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: 05-500 11826

Applicant:

Address:

Date Evaluated:

Proposed Facility:

Design Flow (.1949): 360

Property Size:

Location of Site:

Property Recorded:

Water Supply:

- Public Individual Well Spring Other

Evaluation Method:

- Auger Boring Pit Cut

Type of Wastewater:

- Sewage Industrial Process Mixed

P R O F I L E #	1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
		0-18	GR SL	VFA SF					
		18-24	SBK SL	FR SF					
		24-38	SBK SL	FZ SE	CR 2 C 38	38			.3
		0-24	GR SL	VFA SF					
		24-38	SBK SL	FR SF					
		38-42	SBK SL	FZ SF	CR 2 C 42	42			.3
		0-24	GR SL	VFA SF					
		24-38	SBK SL	FR SF					
		38-42	SBK SL	FZ SF	CR 2 C 42	42			.3
		0-18	GR SL	VFA SF					
		18-30	SBK SL	FR SF					
		30-42	SBK SL	FZ SF	CR 2 C 42	42			.3
		0-18	GR SL	VFA SF					
		18-30	SBK SL	FR SF					
		30-42	SBK SL	FZ SF	CR 2 C 42	42			.3

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	CRAAI	LPI
Site LTAR	.4	.2

1x400 360 LF

Other Factors (.1946): _____
 Site Classification (.1948): P1
 Evaluated By: JWA
 Others Present: JS.

COMMENTS: _____

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE	NS-NON-STICKY
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FR-FRIABLE	SS-SLIGHTLY STICKY
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE	III	SI-SILT-	0.6 - 0.3	FI-FIRM	S-STICKY
H-HEAD SLOPE		SIL-SILT LOAM			
CC-CONCLAVE SLOPE		CL-CLAY LOAM			
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			
T-TERRACE		SICL-SILTY CLAY LOAM			
FP-FLOOD PLAN	IV	SIC-SILTY CLAY	0.4 - 0.1	EFI-EXTREMELY FIRM	VS-VERY STICKY
		C-CLAY			NP-NON-PLASTIC
		SC-SANDY CLAY			SP-SLIGHTLY STICKY
					P-PLASTIC
					VP-VERY PLASTIC


STRUCTURE


- SG-SINGLE GRAIN
- M-MASSIVE
- CR-CRUMB
- GR-GRANULAR
- SBK-SUBANGULAR BLOCKY
- ABK-ANGULAR BLOCKY
- PL-PLATY
- PR-PRISMATIC

MINERALOGY

- SLIGHTLY EXPANSIVE
- EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).





8-

98.360'
11181
00/11

Handwritten notes:
 1. 10' 10" 10'
 2. 10' 10" 10'
 3. 10' 10" 10'

SITE PLAN APPROVAL
 DISTRICT RAZOR USE SFD
 #BEDROOMS 3
4/6/05 ppr
 Date Zoning Administrator

AL = 78'-6 1/2"
 R = 50'-0"
 Δ = 90.0015

S&K HOMES LLC.
 THE CAPE W/SUNROOM
 LOT #172 CRESTVIEW
 SCALE: 1"=40'

Permit Copy

Handwritten notes:
 1. 10' 10" 10'
 2. 10' 10" 10'
 3. 10' 10" 10'

